

Source Water Protection Plan

Red Sulphur PSD

PWSID WV3303206

Monroe County

April 2016

Prepared by:

Tetra Tech, Inc.

803 Quarrier Street, Suite 400

Charleston, WV 25314

In cooperation with Red Sulphur PSD



This page is intentionally blank.

John Beckman

Preparer's Name

Source Water Specialist

Title of Preparer

Tetra Tech, Inc.

Name of Contractor(s)/Consultant(s)

I certify the information in the source water protection plan is complete and accurate to the best of my knowledge.

Porter Robertson

Signature of responsible party or designee authorized to sign for water utility:

Porter Robertson

Print Name of Authorizing Signatory (see instructions):

Operator / Manager

Title of Authorizing Signatory:

04 / 12 / 2016

Date of Submission (mm/dd/yyyy):

This page is intentionally blank.

TABLE OF CONTENTS

1.0 PURPOSE	1
1.1 What are the benefits of preparing a Source Water Protection Plan?	1
2.0 BACKGROUND: WV SOURCE WATER ASSESSMENT AND PROTECTION PROGRAM	2
3.0 STATE REGULATORY REQUIREMENTS	3
4.0 SYSTEM INFORMATION	4
5.0 WATER TREATMENT AND STORAGE	5
6.0 DELINEATIONS	7
7.0 PROTECTION TEAM	9
8.0 POTENTIAL SOURCES OF SIGNIFICANT CONTAMINATION	11
8.1 Confidentiality of PSSCs.....	11
8.2 Local and Regional PSSCs	11
8.3 Prioritization of Threats and Management Strategies	13
9.0 IMPLEMENTATION PLAN FOR MANAGEMENT STRATEGIES	14
10.0 EDUCATION AND OUTREACH STRATEGIES	19
11.0 CONTINGENCY PLAN	22
11.1 Response Networks and Communication	22
11.2 Operation During Loss of Power.....	23
11.3 Future Water Supply Needs	24
11.4 Water Loss Calculation.....	24
11.5 Early Warning Monitoring System	25
12.0 SINGLE SOURCE FEASIBILITY STUDY	28
13.0 COMMUNICATION PLAN	29
14.0 EMERGENCY RESPONSE	30
15.0 CONCLUSION	31

LIST OF TABLES

Table 1. Population Served by Red Sulphur PSD.....	4
Table 2. Red Sulphur PSD Water Treatment Information.....	5
Table 3. Red Sulphur PSD Surface Water Sources	6
Table 4. Red Sulphur PSD Groundwater Sources.....	6
Table 5. Watershed Delineation Information.....	8
Table 6. Protection Team Member and Contact Information	10
Table 7. Locally Identified Potential Sources of Significant Contamination	12
Table 8. Priority PSSCs or Critical Areas.....	15
Table 9. Priority PSSC Management Strategies.....	16
Table 10. Education and Outreach Implementation Plan	20
Table 11. Red Sulphur PSD Water Shortage Response Capability	22
Table 12. Generator Capacity	23
Table 13. Future Water Supply Needs for Red Sulphur PSD	24
Table 14. Water Loss Information	25
Table 15. Early Warning Monitoring System Capabilities	26

APPENDICES

- Appendix A. Figures
- Appendix B. Early Warning Monitoring System Forms
- Appendix C. Communication Plan Template
- Appendix D. Single Source Feasibility Study
- Appendix E. Supporting Documentation

SOURCE WATER PROGRAM ACRONYMS

AST	Aboveground Storage Tank
BMP	Best Management Practices
ERP	Emergency Response Plan
GWUDI	Ground Water Under the Direct Influence of Surface Water
LEPC	Local Emergency Planning Committee
OEHS/EED	Office of Environmental Health Services/Environmental Engineering Division
PE	Professional Engineer
PSSCs	Potential Source of Significant Contamination
PWSU	Public Water System Utility
RAIN	River Alert Information Network
RPDC	Regional Planning and Development Council
SDWA	Safe Drinking Water Act
SWAP	Source Water Assessment and Protection
SWAPP	Source Water Assessment and Protection Program
SWP	Source Water Protection
SWPP	Source Water Protection Plan
WARN	Water/Wastewater Agency Response Network
WHPA	Wellhead Protection Area
WHPP	Wellhead Protection Program
WSDA	Watershed Delineation Area
WVBPH	West Virginia Bureau for Public Health
WVDEP	West Virginia Department of Environmental Protection
WVDHHR	West Virginia Department of Health and Human Resources
WVDHSEM	West Virginia Division of Homeland Security and Emergency Management
ZCC	Zone of Critical Concern
ZPC	Zone of Peripheral Concern

1.0 PURPOSE

The goal of the West Virginia Bureau of Public Health (WVBPH) source water assessment and protection (SWAP) program is to prevent degradation of source waters which may preclude present and future uses of drinking water supplies to provide safe water in sufficient quantity to users. The most efficient way to accomplish this goal is to encourage and oversee source water protection on a local level. Many aspects of source water protection may be best addressed by engaging local stakeholders.

The intent of this document is to describe what Red Sulphur PSD has done, is currently doing, and plans to do to protect its source of drinking water. Although this water system treats the water to meet federal and state drinking water standards, conventional treatment does not fully eradicate all potential contaminants and treatment that goes beyond conventional methods is often very expensive. By completing this plan, Red Sulphur PSD acknowledges that implementing measures to minimize and mitigate contamination can be a relatively economical way to help ensure the safety of the drinking water.

1.1 WHAT ARE THE BENEFITS OF PREPARING A SOURCE WATER PROTECTION PLAN?

- Fulfilling the requirement for the public water utilities to complete or update their source water protection plan.
- Identifying and prioritizing potential threats to the source of drinking water; and establishing strategies to minimize the threats.
- Planning for emergency response to incidents that compromise the water supply by contamination or depletion, including how the public, state, and local agencies will be informed.
- Planning for future expansion and development, including establishing secondary sources of water.
- Ensuring conditions to provide the safest and highest quality drinking water to customers at the lowest possible cost.
- Providing more opportunities for funding to improve infrastructure, purchase land in the protection area, and other improvements to the intake or source water protection areas.

2.0 BACKGROUND: WV SOURCE WATER ASSESSMENT AND PROTECTION PROGRAM

Since 1974, the federal Safe Drinking Water Act (SDWA) has set minimum standards on the construction, operation, and quality of water provided by public water systems. In 1986, Congress amended the SDWA. A portion of those amendments were designed to protect the source water contribution areas around ground water supply wells. This program eventually became known as the Wellhead Protection Program (WHPP). The purpose of the WHPP is to prevent pollution of the source water supplying the wells.

The Safe Drinking Water Act Amendments of 1996 expanded the concept of wellhead protection to include surface water sources under the umbrella term of Source Water Protection. The amendments encourage states to establish SWAP programs to protect all public drinking water supplies. As part of this initiative states must explain how protection areas for each public water system will be delineated, how potential contaminant sources will be inventoried, and how susceptibility ratings will be established.

In 1999, the WVBPH published the West Virginia Source Water Assessment and Protection Program, which was endorsed by the United States Environmental Protection Agency. Over the next few years, WVBPH staff completed an assessment (i.e., delineation, inventory and susceptibility analysis) for all of West Virginia's public water systems. Each public water system was sent a copy of its assessment report. Information regarding assessment reports for Red Sulphur PSD can be found in **Table 1**.

3.0 STATE REGULATORY REQUIREMENTS

On June 6, 2014, §16 1 2 and §16 1 9a of the Code of West Virginia, 1931, was reenacted and amended by adding three new sections, designated §16 1 9c, §16 1 9d and §16-1-9e. The changes to the code outlines specific requirements for public water utilities that draw water from a surface water source or a surface water influenced groundwater source.

Under the amended and new codes each existing public water utility using surface water or ground water influenced by surface water as a source must have completed or updated a source water protection plan by July 1, 2016, and must continue to update their plan every three years. Existing source water protection plans have been developed for many public water utilities in the past. If available, these plans were reviewed and considered in the development of this updated plan. Any new water system established after July 1, 2016 must submit a source water protection plan before they start to operate. A new plan is also required when there is a significant change in the potential sources of significant contamination (PSSC) within the zone of critical concern (ZCC).

The code also requires that public water utilities include details regarding PSSCs, protection measures, system capacities, contingency plans, and communication plans. Before a plan can be approved, the local health department and public will be invited to contribute information for consideration. In some instances, public water utilities may be asked to conduct independent studies of the source water protection area and specific threats to gain additional information.

4.0 SYSTEM INFORMATION

Red Sulphur PSD is classified as a state regulated public utility and operates a community public water system. A community public water system is a system that regularly supplies drinking water from its own sources to at least 15 service connections used by year round residents of the area or regularly serves 25 or more people throughout the entire year. For purposes of this source water protection plan, community public water systems are also referred to as public water utilities. Information on the population served by this utility is presented in **Table 1** below.

Table 1. Population Served by Red Sulphur PSD

Administrative office location:	200 Market Street, Peterstown, WV 24963		
Is the system a public utility, according to the Public Service Commission rule?	Yes		
Date of Most Recent Source Water Assessment Report:	March 2005		
Date of Most Recent Source Water Protection Plan:	April 2011		
Population served directly:	2,198 customers (from 2014 PSC Annual Report).		
Bulk Water Purchaser Systems:	System Name	PWSID Number	Population
	N/A	N/A	N/A
	N/A	N/A	N/A
Total Population Served by the Utility:	5,352 (according to Contingency Plan)		
Does the utility have multiple source water protection areas (SWPAs)?	Yes		
How many SWPAs does the utility have?	4 Total: Rich Creek, Coburn Spring, Hancock Spring, and well at the plant.		

5.0 WATER TREATMENT AND STORAGE

As required, Red Sulphur PSD has assessed their system (e.g., treatment capacity, storage capacity, unaccounted for water, contingency plans) to evaluate their ability to provide drinking water and protect public health. **Table 2** contains information on the water treatment methods and capacity of the utility. Information about the surface sources from which Red Sulphur PSD draws water can be found in **Table 3**. If the utility draws water from any groundwater sources to blend with the surface water the information about these ground water sources can be found in **Table 4**.

Table 2. Red Sulphur PSD Water Treatment Information

Water Treatment Processes (List All Processes in Order)	Water treatment processes include aeration, coagulation, sedimentation, chlorination, and fluoridation.
Current Treatment Capacity (gal/day)	The current treatment capacity of the water plant is about 1,000,000 gallons/day.
Current Average Production (gal/day)	Current average production is about 360,000 gallons/day.
Maximum Quantity Treated and Produced (gal)	The maximum amount of water produced in the last calendar year was 517,000 gallons on 1/9/14
Minimum Quantity Treated and Produced (gal)	The minimum amount of water produced in the last calendar year was 287,000 gallons on 7/31/14
Average Hours of Operation	The plant is operated an average of 9 hours/day.
Maximum Hours of Operation in One Day	12 hours/day
Minimum Hours of Operation in One Day	0 hours/day
Number of Storage Tanks Maintained	The utility maintains seven treated water storage tanks and seven booster stations.
Total Gallons of Treated Water Storage (gal)	The total treated water storage capacity of Red Sulphur PSD is around 1,174,000 gallons. (1,318,00 gallons according to Contingency Plan)
Total Gallons of Raw Water Storage (gal)	300,000 gallons (according to Contingency Plan)

Table 3. Red Sulphur PSD Surface Water Sources

Intake Name	SDWIS #	Local Name	Describe Intake	Name of Water Source	Date Constructed / Modified	Frequency of Use (Primary/ Backup/ Emergency)	Activity Status (Active/ Inactive)
Rich Creek Intake -		Rich Creek Intake	Gravity feed with screens to raw water pump	Rich Creek	1990's	Backup	Active
Hancock Spring		Hancock	Gravity feed with screens to raw water pump	Hancock Spring	1934,1960 /1992	Primary Upper	Active
Coburn Spring		Hancock	Gravity feed with screens to raw water pump	Coburn Spring	1934,1960 /1992	Primary Lower	Active

Table 4. Red Sulphur PSD Groundwater Sources

Does the utility blend with groundwater?					Only in dry weather				
Well/Spring Name	SDWIS #	Local Name	Date Constructed/ Modified	Completion Report Available (Yes/No)	Well Depth (ft)	Casing Depth (ft)	Grout (Yes/No)	Frequency of Use (Primary/ Backup/ Emergency)	Activity Status (Active/ Inactive)
Well at the Plant		Plant Well	1993	No			Yes	Backup	Active

6.0 DELINEATIONS

For surface water systems, delineation is the process used to identify and map the drainage basin that supplies water to a surface water intake. This area is generally referred to as the source water protection area (SWPA). All surface waters are susceptible to contamination because they are exposed at the surface and lack a protective barrier from contamination. Accidental spills, releases, sudden precipitation events that result in overland runoff, or storm sewer discharges can allow pollutants to readily enter the source water and potentially contaminate the drinking water at the intake. The SWPA for surface water is distinguished as a Watershed Delineation Area (WSDA) for planning purposes; and the Zone of Peripheral Concern (ZPC) and Zone of Critical Concern (ZCC) are defined for regulatory purposes.

The WSDA includes the entire watershed area upstream of the intake to the boundary of the State of West Virginia border, or a topographic boundary. The ZCC for a public surface water supply is a corridor along streams within the watershed that warrants more detailed scrutiny due to its proximity to the surface water intake and the intake's susceptibility to potential contaminants within that corridor. The ZCC is determined using a mathematical model that accounts for stream flows, gradient and area topography. The length of the ZCC is based on a five-hour time-of-travel of water in the streams to the water intake, plus an additional one-quarter mile below the water intake. The width of the zone of critical concern is one thousand feet measured horizontally from each bank of the principal stream and five hundred feet measured horizontally from each bank of the tributaries draining into the principal stream. Ohio River ZCC delineations are based on ORSANCO guidance and extend 25 miles above the intake and one-quarter mile below the intake. The Ohio River ZCC delineations include 1,320 feet (one-quarter mile) measured from the bank of the main stem of the Ohio River and 500 feet on tributary.

The ZPC for a public surface water supply source and for a public surface water influenced groundwater supply source is a corridor along streams within a watershed that warrants scrutiny due to its proximity to the surface water intake and the intake's susceptibility to potential contaminants within that corridor. The ZPC is determined using a mathematical model that accounts for stream flows, gradient and area topography. The length of the zone of peripheral concern is based on an additional five-hour time-of-travel of water in the streams beyond the perimeter of the zone of critical concern, which creates a protection zone of ten hours above the water intake. The width of the zone of peripheral concern is one thousand feet measured horizontally from each bank of the principal stream and five hundred feet measured horizontally from each bank of the tributaries draining into the principal stream.

For groundwater supplies there are two types of SWPA delineations: 1) wellhead delineations and 2) conjunctive delineations, which are developed for supplies identified as groundwater under the direct influence of surface water, or GWUDIs. A wellhead protection area is determined to be the area contributing to the recharge of the groundwater source (well or spring), within a five year time of travel. A conjunctive delineation combines a wellhead protection area for the hydrogeologic recharge and a connected surface area contributing to the wellhead.

Information and maps of the WSDA, ZCC, ZPC and Wellhead Protection Area for this public water supply were provided to the utility and are attached to this report. See **Appendix A. Figures**. Other information about the WSDA is shown in **Table 5**.

Table 5. Watershed Delineation Information

Size of WSDA (Indicate units)	27 square miles
River Watershed Name (8-digit HUC)	Upper New River Watershed - 05050001
Size of Zone of Critical Concern (Acres)	The ZCC covers approximately 9,019 acres.
Size of Zone of Peripheral Concern (Acres) (Include ZCC area)	The ZPC does not extend beyond the ZCC because Rich Creek is a relatively small watershed.
Method of Delineation for Groundwater Sources	Coburn Spring was delineated using available hydrogeologic data
Area of Wellhead Protection Area (Acres)	556 acres

7.0 PROTECTION TEAM

One important step in preparing a source water protection plan is to organize a source water protection team who will help develop and implement the plan. The legislative rule requires that water utilities make every effort to inform and engage the public, local government, local emergency planners, the local health department and affected residents at all levels of the development of the protection plan. WVBPH recommends that the water utility invite representatives from these organizations to join the protection team, which will ensure that they are given an opportunity to contribute in all aspects of source water protection plan development. Public water utilities should document their efforts to engage representatives and provide an explanation if any local stakeholder is unable to participate. In addition, other local stakeholders may be invited to participate on the team or contribute information to be considered. These individuals may be emergency response personnel, local decision makers, business and industry representatives, land owners (of land in the protection area), and additional concerned citizens.

The administrative contact for Red Sulphur PSD is responsible for assembling the protection team and ensuring that members are provided the opportunity to contribute to the development of the plan. The acting members of the Protection Team are listed in **Table 6**.

The role of the protection team members will be to contribute information to the development of the source water protection plan, review draft plans and make recommendations to ensure accuracy and completeness, and when possible contribute to implementation and maintenance of the protection plan. The protection team members are chosen as trusted representatives of the community served by the water utility and may be designated to access confidential data that contains details about the local PSSCs. The input of the protection team will be carefully considered by the water utility when making final decisions relative to the documentation and implementation of the source water protection plan.

Red Sulphur PSD will be responsible for updating the source water protection plan and rely upon input from the protection team and the public to better inform their decisions. To find out how you can become involved as a participant or contributor, visit the utility website or call the utility phone number, which are provided in **Table 6**.

Table 6. Protection Team Member and Contact Information

Name	Representing	Title	Phone Number	Email
Porter Robertson	Red Sulphur PSD	Chief Operator	304-753-5981	probertson4@rocketmail.com
Darrell Shrewsbury	Red Sulphur PSD	Operator/Engineer	304-753-5981	-
Patty Ramsey	Red Sulphur PSD	Office Manager	304-753-4003	-
Kevin Belcher	Red Sulphur PSD	Board Member	[REDACTED]	kbelcher@gilescounty.org
Jackie Kirby	Monroe County Local Health Department	Environmental Representative	304-772-3064	-
Tim Wilson	Monroe County Office of Emergency Services	Director	304-772-3911	-
Donald Evans	Monroe County Commission	County Clerk	304-772-3096	devans@monroecountywv.net
J.B. Buckland	Property Owner	Property Owner	[REDACTED]	-
Anthony Brown	Thrasher Engineering	Consulting Engineer	304-431-7800	-
Howdy Henritz	Indian Creek Watershed Association	Member	[REDACTED]	howdywv@hughes.net
Date of first protection Team Meeting		February 3, 2016		
Efforts made to inform and engage local stakeholders (public, local government, local emergency planners, local health department, and affected residents) and explain absence of recommended stakeholders:		Public meeting held March 15 at PSD office. See Appendix E for meeting minutes.		

8.0 POTENTIAL SIGNIFICANT SOURCES OF CONTAMINATION

Source water protection plans should provide a complete and comprehensive list of the PSSCs contained within the ZCC based upon information obtained from the WVBPH, working in cooperation with the West Virginia Department of Environmental Protection (WVDEP) and the West Virginia Division of Homeland Security and Emergency Management (WVDHSEM). A facility or activity is listed as a PSSC if it has the potential to release a contaminant that could potentially impact a nearby public water supply, and it does not necessarily indicate that any release has occurred.

The list that utilities receive of PSSCs located in their SWPA is organized into two types: 1) SWAP PSSCs, and 2) Regulated Data. SWAP PSSCs are those that have been collected and verified by the WVBPH SWAP program during previous field investigations to form source water assessment reports and source water protection plans. Regulated PSSCs are derived from federal and state regulated databases, and may include data from WVDEP, US Environmental Protection Agency, WVDHSEM, and out of state data sources.

8.1 CONFIDENTIALITY OF PSSCS

A list of the PSSCs contained within the ZCC should be included in the source water protection plan. However, the exact location, characteristics and approximate quantities of contaminants shall only be made known to one or more designees of the public water utility and maintained in a confidential manner. In the event of a chemical spill, release or other related emergency, information pertaining to the contaminant shall be immediately disseminated to any emergency responders reporting to the site. The designees for Red Sulphur PSD are identified in the communication planning section of the source water protection plan.

PSSC data from some agencies (ex. WVDHSEM, WVDEP, etc.) may be restricted due to the sensitive nature of the data. Locational data will be provided to the public water utility. However, to obtain specific details regarding contaminants, (such as information included in Tier II reports), water utilities should contact the local emergency planning commission (LEPC) or agencies, directly. While the maps and lists of the PSSCs and regulated sites are to be maintained in a confidential manner, these data are provided in **Appendix A. Figures** for internal review and planning uses only.

8.2 LOCAL AND REGIONAL PSSCS

For the purposes of this source water protection plan, local PSSCs are those that are identified by local stakeholders in addition to the PSSCs lists distributed by the WVBPH and other agencies. Local stakeholders may identify local PSSCs for two main reasons. The first is that it is possible that threats exist from unregulated sources and land uses that have not already been inventoried and do not appear in regulated databases. For this reason each public water utility should investigate their protection area for local PSSCs. A PSSC inventory should identify all contaminant sources and land uses in the delineated ZCC. The second reason local PSSCs are identified is because public water utilities may consider expanding the PSSC inventory effort outside of the ZCC into the ZPC and WSDA if necessary to properly identify all threats that could impact the drinking water source. As the utility considers threats in the watershed they may consider collaborating with upstream communities to identify and manage regional PSSCs.

When conducting local and regional PSSC inventories, utilities should consider that some sources may be obvious like above ground storage tanks, landfills, livestock confinement areas, highway or railroad right of ways, and sewage treatment facilities. Others are harder to locate like abandoned cesspools, underground tanks, French drains, dry wells, or old dumps and mines.

Red Sulphur PSD reviewed intake locations and the delineated SWPAs to verify the existence of PSSCs provided by the WVBPH and identify new PSSCs. If possible, locations of regulated sites within the SWPA were confirmed. Information on any new or updated PSSCs identified by Red Sulphur PSD and not already appearing in datasets from the WVBPH can be found in **Table 7**.

Table 7. Locally Identified Potential Sources of Significant Contamination

PSSC Number	Map Code	Site Name	Site Description	Relative Risk Score	Comments
N/A	N/A	New Mountain Valley Pipeline	New 42 inch natural gas pipeline proposed to be constructed across several miles of Rich Creek Watershed.	High	Construction activity would increase the probability of petroleum releases from trucks and heavy equipment working to build the pipeline. Once constructed, the normal pipeline operations would constitute a reduced threat.

8.3 PRIORITIZATION OF POTENTIAL THREATS AND MANAGEMENT STRATEGIES

Once the utility has identified local concerns, they must develop a management plan that identifies specific activities that will be pursued by the public water utility in cooperation and concert with the WVBPH, local health departments, local emergency responders, LEPC and other agencies and organizations to protect the source water from contamination threats.

Depending on the number identified, it may not be feasible to develop management strategies for all of the PSSCs in the SWPA. The identified PSSCs can be prioritized by potential threat to water quality, proximity to the intake(s), and local concern. The highest priority PSSCs can be addressed first in the initial management plan. Lower ranked PSSCs can be addressed in the future as time and resources allow. To assess the threat to the source water, water systems should consider confidential information about each PSSC. This information may be obtained from state or local emergency planning agencies, Tier II reports, facility owner, facility groundwater protection plans, spill prevention response plans, results of field investigations, etc.

In addition to identifying and prioritizing PSSCs within the SWPA, local source water concerns may also focus on critical areas. For the purposes of this source water protection plan, a critical area is defined as an area that is identified by local stakeholders and can lie within or outside of the ZCC. Critical areas may contain one or more PSSCs which would require immediate response to address a potential incident that could impact the source water.

A list of priority PSSCs was selected and ranked by the Red Sulphur Protection Team. This list reflects the concerns of this specific utility and may contain PSSCs not previously identified and not within the ZCC or ZPC. **Table 8** contains a description of why each critical area or PSSC is considered a threat and what management strategies the utility is either currently using or could use in the future to address each threat.

9.0 IMPLEMENTATION PLAN FOR MANAGEMENT STRATEGIES

Red Sulphur PSD reviewed the recommended strategies listed in their previous source water protection plan, to consider if any of them should be adopted and incorporated in this updated plan. **Table 9** provides a brief statement summarizing the status of the recommended strategies. **Table 9** also lists strategies from a previous plan that are being incorporated in this plan update

When considering source management strategies and education and outreach strategies, this utility has considered how and when the strategies will be implemented. The initial step in implementation is to establish responsible parties and timelines to implement the strategies. The water utility, working in conjunction with the Protection Team members, can determine the best process for completing activities within the projected time periods. Additional meetings may be needed during the initial effort to complete activities, after which the Protection Team should consider meeting annually to review and update the Source Water Protection Plan. A system of regular updates should be included in every implementation plan.

Proposed commitments and schedules may change but should be well documented and reported to the local stakeholders. If possible, utilities should include cost estimates for strategies to better plan for implementation and possible funding opportunities. Red Sulphur PSD has developed an implementation plan for priority concerns listed in **Table 8**. The responsible team member, timeline, and potential cost of each strategy are presented in **Table 9**. Note: Because timelines may change, future plan updates should describe the status of each strategy and explain the lack of progress.

Table 8. Priority PSSCs or Critical Areas

PSSC or Critical Area	Priority Number	Reason for Concern
Surface Water Vulnerability to Future Development	1	The Mountain Valley Pipeline project is a new 42 inch natural gas pipeline proposed to be constructed across several miles of the Rich Creek Watershed. Construction activity would increase the probability of petroleum releases from trucks and heavy equipment working to build the pipeline. Once constructed, the normal pipeline operations would constitute a reduced threat.
Groundwater Vulnerability to Future Development	2	Given that the water system is located in karst geology, the groundwater is susceptible to contamination much like the surface water source. Future development of the Peterstown area, including the spring recharge area on Peters Mountain, could result in reduced water quality and quantity. The Fountain Spring Industrial Park is being developed within the ZCC. Depending upon the facility, accidental incidents, chemicals releases, stormwater runoff, and increased traffic could impact the surface water.
Potential Future Marcellus Shale Wells	3	<p>Fracturing fluid is typically water and sand that is forced into the shale to open cracks and fissures so more natural gas can flow out of the formation. Chemicals can also be added to this fluid. Brine water is a byproduct of Marcellus Shale Wells. There are several methods to dispose of this fluid, such as deep injection and trucking the fluid to a treatment facility. If not properly stored and transported, fracturing water, as well as brine water from the wells, may be spilled into the source water. Water for the fracturing process may be obtained from local surface water resources. Depending upon flow, the removal of water or the accidental contamination of water could impact the source water intake.</p> <p>Gas wells of all types, when properly drilled in accordance with their permits, do not pose an imminent danger. However, brine removed from the wells must be collected and handled properly to prevent contamination to the surface and ground waters. Also, road cuts to access gas well sites may create erosion issues that can cause increased sediments and turbidity in surface waters.</p>
Highway Traffic	4	Highways run within the watershed and cross the ZCC. If an accident were to occur, it may be difficult to contain spill materials and these could potentially contaminate the surface water.
Agricultural Land Use and Golf Course	5	Pesticides and other chemicals used for farm operations can migrate into the water supply. Areas used for disposal of animal waste or burying dead livestock can also cause contamination of the source water. Likewise, fertilizers and pesticides used to maintain the golf course could contaminate source waters.
Individual septic systems	6	Failing septic systems can leach into surrounding soils and potentially contaminate the water supply.
Potential line breaks from public sewer near surface water	7	If a line break occurs, untreated sewage, could contaminate the surface water source, raising concentrations of total coliform, particularly fecal coliform.

PSSC or Critical Area	Priority Number	Reason for Concern
Power line, pipeline, and highway rights-of-way (ROWs)	8	ROWs are typically maintained with herbicides that can migrate into the water supply. Highway road salt use can also migrate into the water supply.

Table 9. Priority PSSC Management Strategies

PSSC or Critical Area	Management Activity	Responsible Protection Team Member	Status/Schedule	Comments	Estimated Cost
Previous Plan Status	There were 9 management strategies recommended in the existing plan. One of these strategies have been accomplished. Seven of these are ongoing or continue to be a concern. These are incorporated in this plan update and listed below.	-	-	-	-
Source Water Protection Area	The utility is required to update the Source Water Protection Plan at least every 3 years and continue to monitor any ongoing or new activities that occur in the watershed.	PSD operator, staff, or board member.	Ongoing every 3 years. Next update in 2018	-	-
Surface Water Vulnerability to Future Development	Communicate with Mountain Valley Pipeline officials to better understand specific threats to surface water quality, and insist that the pipeline company implement management practices to protect water quality.	PSD operator, staff, or board member.	-	-	-
Groundwater Vulnerability to Future Development	Participated in the development of the Monroe County Comprehensive Plan.	PSD operator, staff, or board member.	Plan was completed July 2009 after three years of development.	The plan prioritizes abundant, clean water in the County Commission's mission. As the commission develops their plan and directs growth in the future, one guideline listed and described as supportive and directive to their	Red Sulphur PSD contributed funding secured through a grant from the WVDHHR SWAP

				efforts is to identify and prevent potential threats to water quality.	Source Water Protection Grant Program.
Groundwater and Surface Water Vulnerability to Future Development	As the industrial park is developed, investigate the facilities constructed in the park. Depending upon the facility they may be required to obtain NPDES permits and complete Groundwater Protection Plans. Ask that the SWPA be considered during development and that facilities follow BMPs to protect water resources.	PSD operator, staff, or board member.	In the future as needed.	To provide a map of the SWPA and find out more information, contact the Greenbrier Valley Economic Development Corp at PO Box 33, Maxwelton, WV 24957, or by phone: 304-497-4300, website: http://www.gvedc.com/facilities.aspx?r=2	-
Agricultural Land Use and Golf Course	Provide copies of fact sheets covering BMPs for nutrient management, pesticide use, pest management, waste oil disposal, safe chemical handling and/or safe chemical storage. Work with the local livestock owners to determine the placement of animal waste disposal areas and/or areas for burying dead livestock.	PSD operator, staff, or board member.	Within 1 year.	Work with the WVU Extension, Monroe County Farmland Protection Program, the Soil and Water Conservation District, and/or the Natural Resource Conservation Service.	Minimal costs associated with operator's time.
Individual septic systems	Provide information regarding contamination and source water protection in mailings to homeowners and include non-emergency contact information. Outreach materials will encourage them to have their septic system inspected regularly and pumped every 5-10 years as needed.	PSD operator, staff, or board member.	Within 1 year.	May receive assistance through the Monroe County Health Department. Also, the USEPA provides a complete guide for residents to maintain their septic systems, for the guide, visit: http://epa.gov/owm/septic/pubs/homeowner_guide_long.pdf .	-
Individual septic Systems	The utility will also consider reducing the amount of septic systems in use by extension of the public wastewater system.	PSD operator, staff, or board member.	Ongoing	-	-

<p>Potential line breaks from public sewer near surface water</p>	<p>Continue to communicate with coworkers at Red Sulphur PSD wastewater system to raise awareness of the source water vulnerability to contamination from leaking lines.</p>	<p>PSD operator, staff, or board member.</p>	<p>Ongoing</p>	<p>-</p>	<p>Minimal costs associated with operator's time.</p>
<p>Power line, pipeline, and highway rights-of-way (ROWs)</p>	<p>Contact the electric utility and WVDOH to determine the herbicides used within the ROWs and any other chemicals used. Communicate the boundaries of the SWPA to raise awareness and ensure BMPs.</p>	<p>PSD operator, staff, or board member.</p>	<p>Within 1 year.</p>	<p>Herbicide labeling is developed with guidance from the USEPA providing information on application. This guidance has been developed with public health in mind and may list restrictions for application to prevent herbicide migration into water supplies.</p>	<p>Minimal costs associated with operator's time.</p>

10.0 EDUCATION AND OUTREACH STRATEGIES

The goal of education and outreach is to raise awareness of the need to protect drinking water supplies and build support for implementation strategies. Education and outreach activities will also ensure that affected citizens and other local stakeholders are kept informed and provided an opportunity to contribute to the development of the source water protection plan. Red Sulphur PSD has created an Education and Outreach plan that describes activities it has either already implemented or could implement in the future to keep the local community involved in protecting their source of drinking water. This information can be found in **Table 10**.

Table 10. Education and Outreach Implementation Plan

Education and Outreach Strategy	Description of Activity	Responsible Protection Team Member	Status/Schedule	Comments	Estimated Cost
Consumer Confidence Report	The water system publishes a Consumer Confidence Report (CCR) annually, as required by the Safe Drinking Water Act, which is sent to all water customers. Information concerning the Source Water Assessment is included in the CCR. In the future, the system will include a reference to this source water protection plan and how customers can access a copy.	PSD operator, staff, or board member.	Annually	This would be in addition to required Source Water Assessment information, including source of water and susceptibility to contamination.	CCR required by SDWA, included in annual budget.
Communicate Through Social Media	Maintain PSD Website www.redsulphurpsd.com and PSD Facebook Page.	PSD administrative staff	Ongoing – as needed	Facebook and PSD website were used to inform customers during July 2015 contamination event. Social media postings significantly reduced call volume to PSD office.	Minimal cost associated with admin staff time.
School Curricula	Coordinate with educators to include source water protection information in school curricula.	PSD operator, staff, or board member.	Within 5 years	Can provide websites with free education materials to promote source water protection and conservation. Also operator may visit school or invite students for a plant tour to tie in with classroom materials.	Minimal costs. Would require time to coordinate, visit classroom and provide tour.
Plant Tours	Conduct plant tours for emergency responders, students, and interest groups.	PSD operator, staff, or board member.	Ongoing – as requested	-	Minimal cost associated with operator's time.
Participate in WVU research project	WVU has conductivity, pH monitors in two springs. Checked every three months. Paid for by WVU research grant.	WVU graduate students	Ongoing	-	Minimal cost associated with operator's time.

<p>Emergency Planning and Coordination</p>	<p>Participate with local fire departments and County Emergency Services when training is organized. This will ensure that all the agencies are in constant communication with one another and prepared in the event of an emergency.</p> <p>911 Map software for homes, flood zones, streams, streets, hydrants, water mains developed by Monroe County 911, available to PSD for working with customers.</p>	<p>PSD operator, staff, or board member.</p>	<p>Ongoing and continuing annually</p>	<p>-</p>	<p>Cost associated with participation in training activities.</p>
<p>Partner with Watershed Association</p>	<p>Partnered with Indian Creek Watershed, Friends of The Second Creek and other civic groups when developing the Monroe County Comprehensive Plan. These groups have similar goals and available volunteers that can integrate source water protection into their efforts.</p>	<p>PSD operator, staff, or board member.</p>	<p>Monthly/ annually</p>	<p>Watershed Associations have monthly meeting and conduct public outreach on a yearly basis.</p>	<p>Cost associated with participation in activities.</p>
<p>Public Meeting</p>	<p>Participated in informational meeting with local residents about source water protection efforts. Will consider conducting meetings in the future if needed. The meeting will increase awareness of the connection between land use and drinking water quality. This meeting could be structured as a water fair/public event with drinking water displays and activities. This can be combined with activities of the local watershed associations.</p>	<p>PSD operator, staff, or board member.</p>	<p>In future if needed.</p>	<p>May be structured as a water fair.</p>	<p>Minimal cost related to operator time.</p>

11.0 CONTINGENCY PLAN

The goal of contingency planning is to identify and document how the utility will prepare for and respond to any drinking water shortages or emergencies that may occur due to short and long term water interruption, or incidents of spill or contamination. During contingency planning, utilities should examine their capacity to protect their intake, treatment, and distribution system from contamination. They should also review their ability to use alternative sources and minimize water loss, as well as their ability to operate during power outages. In addition, utilities should report the feasibility of establishing an early warning monitoring system and meeting future water demands.

Isolating or diverting any possible contaminant from the intake for a public water system is an important strategy in the event of an emergency. One commonly used method of diverting contaminants from an intake is establishing booms around the intake. This can be effective, but only for contaminants that float on the surface of the water. Alternatively, utilities can choose to pump floating contaminants from the water or chemically neutralize the contaminant before it enters the treatment facility.

Public utilities using surface sources should be able to close the intake by one means or another. However, depending upon the system, methods for doing so could vary greatly and include closing valves, lowering hatches or gates, raising the intake piping out of the water, or shutting down pumps. Systems should have plans in place in advance as to the best method to protect the intake and treatment facility. Utilities may benefit from turning off pumps and, if possible, closing the intake opening to prevent contaminants from entering the piping leading to the pumps. Utilities should also have a plan in place to sample raw water to identify the movement of a contaminant plume and allow for maximum pumping time before shutting down an intake (See Early Warning Monitoring System). The amount of time that an intake can remain closed depends on the water infrastructure and should be determined by the utility before an emergency occurs. The longer an intake can remain closed in such a case, the better.

Raw and treated water storage capacity also becomes extremely important in the event of such an emergency. Storage capacity can directly determine how effectively a water system can respond to a contamination event and how long an intake can remain closed. Information regarding the water shortage response capability of Red Sulphur PSD is provided in **Table 11**.

11.1 RESPONSE NETWORKS AND COMMUNICATION

Statewide initiatives for emergency response, including source water related incidents, are being developed. These include the West Virginia Water/Wastewater Agency Response Network (WV WARN, see <http://www.wvwarn.org/>) and the Rural Water Association Emergency Response Team (see <http://www.wvrwa.org/>). Red Sulphur PSD has analyzed its ability to effectively respond to emergencies and this information is also provided in **Table 11**.

Table 11. Red Sulphur PSD Water Shortage Response Capability

Can the utility isolate or divert contamination from the intake or groundwater supply?	No
Describe the utility's capability to isolate or divert potential contaminants:	N/A
Can the utility switch to an alternative water source or intake that can supply full capacity at any time?	Yes
Describe in detail the utility's capability to switch to an alternative source:	The PSD can switch to an alternative water source by turning gate valves and remotely turning on the booster station.

Can the utility close the water intake to prevent contamination from entering the water supply?	Yes
How long can the intake stay closed?	The intake can remain closed as long as necessary.
Describe the process to close the intake:	The gate valves are closed.
Describe the treated water storage capacity of the water system:	The current water storage capacity of the system consists of 8 tanks totaling 1,318,000 gallons
Is the utility a member of WVRWA Emergency Response Team?	Yes
Is the utility a member of WV-WARN?	Yes
List any other mutual aid agreements to provide or receive assistance in the event of an emergency:	Mutual Aid agreement with Giles County PSA

Information for this table was taken from the Source Water Protection Contingency Plan prepared by The Thrasher Group. The complete report is provided as Appendix D.

11.2 OPERATION DURING LOSS OF POWER

Red Sulphur PSD analyzed its ability to operate effectively during a loss of power. This involved ensuring a means to supply water through treatment, storage, and distribution without creating a public health emergency. Information regarding the utility’s capacity for operation during power outages is summarized in **Table 12**.

Table 12. Generator Capacity

What is the type and capacity of the generator needed to operate during a loss of power?	The emergency generator capacity for the system is portable 100 kW and standby 350 kW.	
Can the utility connect to generator at intake/wellhead? If yes, select a scenario that best describes system.	Yes; there is a generator a 100 kw portable generator.	
Can the utility connect to generator at treatment facility? If yes, select a scenario that best describes system.	Yes; standby power is available using a Caterpillar generator.	
Can the utility connect to a generator in distribution system? If yes, select a scenario that best describes system.	Yes, a portable generator at the plant can be connected to the booster stations	
Does the utility have adequate fuel on hand for the generator?	Yes	
	Gallons	Hours

What is your on-hand fuel storage and how long will it last operating at full capacity?		180 gallons	36 hours
Provide a list of suppliers that could provide generators and fuel in the event of an emergency:	Supplier		Phone Number
	Generator	Caterpillar	(304) 949-6400
	Generator	Cummins	(304) 769-1012
	Fuel	RT Rogers	(304) 466-1733
Does the utility test the generator(s) periodically?		Yes	
Does the utility routinely maintain the generator?		Yes	
If no scenario describing the ability to connect to generator matches the utility's system or if utility does not have ability to connect to a generator, describe plans to respond to power outages:		N/A	

Information for this table was taken from the Source Water Protection Contingency Plan prepared by The Thrasher Group. The complete report is provided as Appendix D.

11.3 FUTURE WATER SUPPLY NEEDS

When planning for potential emergencies and developing contingency plans, a utility needs to not only consider their current demands for treated water but also account for likely future needs. This could mean expanding current intake sources or developing new ones in the near future. This can be an expensive and time consuming process, and any water utility should take this into account when determining emergency preparedness. Red Sulphur PSD has analyzed its ability to meet future water demands at current capacity, and this information is included in **Table 13**.

Table 13. Future Water Supply Needs for Red Sulphur PSD

Is the utility able to meet water demands with the current production capacity over the next 5 years? If so, explain how you plan to do so.	Yes. The Adair Road extension will add 114 customers that will require approximately 40,000 GPD. The water treatment plant is sized at 1 MGD and the current average demand is 350,000 GPD.
If not, describe the circumstances and plans to increase production capacity:	N/A

11.4 WATER LOSS CALCULATION

In any public water system there is a certain percentage of the total treated water that does not reach the customer. Some of this water is used in treatment plant processes such as back washing filters or flushing piping, but there is usually at least a small percentage that goes unaccounted for. To measure and report on this unaccounted for water, a public utility must use the method described in the Public Service Commission's rule, *Rules for the Government of Water Utilities*, 150CSR7, section 5.6. The rule defines unaccounted for water as

the volume of water introduced into the distribution system less all metered usage and all known non-metered usage which can be estimated with reasonable accuracy.

To further clarify, metered usages are most often those that are distributed to customers. Non-metered usages that are being estimated include usage by fire departments for fires or training, un-metered bulk sells, flushing to maintain the distribution system, and water used for backwashing filters and cleaning settling basins. By totaling the known metered and non-metered uses the utility calculates unaccounted for water. Note: To complete annual reports submitted to the PSC, utilities typically account for known water main breaks by estimating the amount of water lost. However, for the purposes of the source water protection plan, any water lost due to leaks, even if the system is aware of how much water is lost at a main break, is not considered a use. Water lost through leaks and main breaks cannot be controlled during a water shortages or other emergencies and should be included in the calculation of percentage of water loss for purposes of the source water protection plan. The data in **Table 14** is taken from the most recently submitted Red Sulphur PSD PSC Annual Report.

Table 14. Water Loss Information

Total Water Pumped (gal)		134,664,000
Total Water Purchased (gal)		0
Total Water Pumped and Purchased (gal)		134,664,000
Water Loss Accounted for Except Main Leaks (gal)	Mains, Plants, Filters, Flushing, etc.	6,850,000
	Fire Department	90,000
	Back Washing	3,100,000
	Blowing Settling Basins	0
Total Water Loss Accounted For Except Main Leaks		10,040,000
Water Sold- Total Gallons (gal)		88,682,000
Unaccounted For Lost Water (gal)		35,942,000
Water lost from main leaks (gal)		0
Total gallons of Unaccounted for Lost Water and Water Lost from Main Leaks (gal)		35,942,000
Total Percent Unaccounted For Water and Water Lost from Main Leaks (gal)		26.69 %
If total percentage of Unaccounted for Water is greater than 15%, please describe any measures that could be taken to correct this problem:		Increase inspections. Older lines are currently being replaced.

*This information was taken from the 2014 Public Service Commission Annual Report for Red Sulphur PSD

11.5 EARLY WARNING MONITORING SYSTEM

Public water utilities are required to provide an examination of the technical and economic feasibility of implementing an early warning monitoring system. Implementing an early warning monitoring system may be approached in different ways depending upon the water utility’s resources and threats to the source water. A utility may install a continuous monitoring system that will provide real time information regarding water quality conditions. This would require utilities to analyze the data to establish what condition is indicative of a contamination event. Continuous monitoring will provide results for a predetermined set of parameters. The more parameters that are being monitored, the more sophisticated the monitoring equipment will need to be. When establishing a continuous monitoring system, the utility should consider the logistics of placing and maintaining the equipment, and receiving output data from the equipment.

Alternately, or in addition, a utility may also pull periodic grab samples on a regular basis, or in case of a reported incident. The grab samples may be analyzed for specific contaminants. A utility should examine their PSSCs to determine what chemical contaminants could pose a threat to the water source. If possible, the utility should plan in advance how those contaminants will be detected. Consideration should be given to where samples will be collected, the preservations and hold times for samples, available laboratories to analyze samples, and costs associated with the sampling event. Regardless of the type of monitoring (continuous or grab), utilities should collect samples for their source throughout the year to better understand the baseline water quality conditions and natural seasonal fluctuations. Establishing a baseline will help determine if changes in the water quality are indicative of a contamination event and inform the needed response.

Every utility should establish a system or process for receiving or detecting chemical threats with sufficient time to respond to protect the treatment facility and public health. All approaches to receiving and responding to an early warning should incorporate communication with facility owners and operators that pose a threat to the water quality, with state and local emergency response agencies, with surrounding water utilities, and with the public. Communication plays an important role in knowing how to interpret data and how to respond.

Red Sulphur PSD has analyzed its ability to monitor for and detect potential contaminants that could impact its source water. Information regarding this utility’s early warning monitoring system capabilities is provided in **Table 15** and in **Appendix B**.

Table 15. Early Warning Monitoring System Capabilities

<p>Does your system currently receive spill notifications from a state agency, neighboring water system, local emergency responders, or other facilities? If yes, from whom do you receive notices?</p>	<p>Yes; the District receives spill notifications from the WV Health Department.</p>	
<p>Are you aware of any facilities, land uses, or critical areas within your protection areas where chemical contaminants could be released or spilled?</p>	<p>Yes; timbering close to the springs, and proposed gas transmission line</p>	
<p>Are you prepared to detect potential contaminants if notified of a spill?</p>	<p>Yes</p>	
<p>List laboratories (and contact information) on whom you would rely to analyze water samples in case of a reported spill.</p>	<p>Laboratories</p>	
	<p>Name</p>	<p>Contact</p>
	<p>REI Consultants</p>	<p>(304) 255-2500</p>
	<p>WV Office of Lab Services</p>	<p>(304) 558-3530</p>
	<p>Analabs</p>	<p>(800)-880-6406</p>

Do you have an understanding of baseline or normal conditions for your source water quality that accounts for seasonal fluctuations?		Yes
Does your utility currently monitor raw water (through continuous monitoring or periodic grab samples) at the surface water intake or from a groundwater source on a regular basis?		No
Provide or estimate the capital and O&M costs for your current or proposed early warning system or upgraded system.	Monitoring System	Hach sc1000 (B-2)
	Capital	\$50,000.00
	Yearly O & M	\$750.00
Do you serve more than 100,000 customers? If so, please describe the methods you use to monitor at the same technical levels utilized by ORSANCO.		No

Information for this table was taken from the Source Water Protection Contingency Plan prepared by The Thrasher Group. The complete report is provided as Appendix D.

12.0 SINGLE SOURCE FEASIBILITY STUDY

If a public water utility's water supply plant is served by a single-source intake to a surface water source of supply or a surface water influenced source of supply, the submitted source water protection plan must also include an examination and analysis of the technical and economic feasibility of alternative sources of water to provide continued safe and reliable public water service in the event that its primary source of supply is detrimentally affected by contamination, release, spill event or other reason. These alternatives may include a secondary intake, two days of additional raw or treated water storage, an interconnection with neighboring systems, or other options identified on a local level. Note: a suitable secondary intake would draw water supplies from a substantially different location or water source.

To accomplish this requirement, utilities should examine all existing or possible alternatives and rank them by their technical, economic, and environmental feasibility. To have a consistent and complete method for ranking alternatives, WVBPH has developed a feasibility study guide. This guide provides several criteria to consider for each category, organized in a Feasibility Study Matrix. By completing the Feasibility Study Matrix, utilities will demonstrate the process used to examine the feasibility of each alternative and document scores that compare the alternatives. The Feasibility Study matrix and summary of the results are presented in an alternatives feasibility study attached as **Appendix D**.

13.0 COMMUNICATION PLAN

Red Sulphur PSD has also developed a Communication Plan that documents the manner in which the public water utility, working in concert with state and local emergency response agencies, shall notify the local health agencies and the public of the initial spill or contamination event and provide updated information related to any contamination or impairment of the system's drinking water supply. The initial notification to the public will occur in any event no later than thirty minutes after the public water system becomes aware of the spill, release, or potential contamination of the public water system. A copy of the source water protection plan and the Communication Plan has been provided to the local fire department. Red Sulphur PSD will update the Communication Plan as needed to ensure contact information is up to date.

Procedures should be in place to effectively react to the kinds of catastrophic spills that can reasonably be predicted at the source location or within the SWPA. The chain-of-command, notification procedures and response actions should be known by all water system employees.

The WVBPH has developed a recommended communication plan template that provides a tiered incident communication process to provide a universal system of alert levels to utilities and water system managers. The comprehensive Communication Plan for Red Sulphur PSD is attached as **Appendix C** for internal review and planning purposes only.

The West Virginia Department of Environmental Protection is capable of providing expertise and assistance related to prevention, containment, and clean-up of chemical spills. The West Virginia Department of Environmental Protection Emergency Response 24-hour Phone is 1-800-642-3074. The West Virginia Department of Environmental Protection also operates an upstream distance estimator that can be used to determine the distance from a spill site to the closest public water supply surface water intake.

14.0 EMERGENCY RESPONSE


A public water utility must be prepared for any number of emergency scenarios and events that would require immediate response. It is imperative that information about key contacts, emergency services, and downstream water systems be posted and readily available in the event of an emergency. Elements of this source water protection plan, such as the contingency planning and communication plan, may contain similar information to the utility's emergency response plan. However, the emergency response plan is to be kept confidential and is not included in this source water protection plan. An Emergency Short Form is included in **Appendix C** to support the Communicate Plan by providing quick access to important information about emergency response and are to be used for internal review and planning purposes only.

15.0 CONCLUSION

This report represents a detailed explanation of the required elements of Red Sulphur PSD's Source Water Protection Plan. Any supporting documentation or other materials that the utility considers relevant to their plan can be found in **Appendix E**.

This source water protection plan is intended to help prepare community public water systems all over West Virginia to properly handle any emergencies that might compromise the quality of the system's source water supply. It is imperative that this plan is updated as often as necessary to reflect the changing circumstances within the water system. The protection team should continue to meet regularly and continue to engage the public whenever possible. Communities taking local responsibility for the quality of their source water is the most effective way to prevent contamination and protect a water system against contaminated drinking water. Community cooperation, sufficient preparation, and accurate monitoring are all critical components of this source water protection plan, and a multi-faceted approach is the only way to ensure that a system is as protected as possible against source water degradation.

APPENDIX A. FIGURES




Legend



Red Sulphur PSD Rich Creek Watershed



Copyright © 2013 National Geographic



Legend

- Red Sulphur PSD Rich Creek ZCC
- Red Sulphur PSD Coburn Spring WHPA
- Red Sulphur PSD Rich Creek Watershed

0 0.5 1 2 Miles



Figure A-2
Zone of Critical Concern and
Wellhead Protection Area

Red Sulphur PSD
PWSID: WV3303206
Source Water Protection Plan

TETRA TECH
803 Quarrer Street, Suite 400
Charleston, WV 25301

DATE: 11/30/15

CREATED BY: JFB

List of Locally Identified PSSCs

PCS No.	Site Name	Site Description	Comments
1	Other animal facilities	Trout Lodge/Fish Hatchery	Trout Lodge with stream, pond, and restaurant
2	Pasture	Dairy Cattle	confirmed location with operator and field investigation
3	Pasture	Crop	confirmed location with operator and field investigation
4	Pasture	Dairy Cattle and Corn Row Crops	confirmed location with operator and field investigation
5	Pasture	Beef Cattle Pastures cover most of the ZCC.	confirmed location with operator and field investigation
6	Pasture	Red Sulphur PSD	Dairy
7	Pasture	Beef Cattle Pastures cover most of the ZCC.	confirmed location with operator and field investigation
8	Pasture	Beef Cattle Pastures cover most of the ZCC.	confirmed location with operator and field investigation
9	Crops, corn, soybean, wheat	Crop	confirmed location with operator and field investigation
10	Pasture	Beef Cattle Pastures cover most of the ZCC.	Named Maple Lawn Farms; confirmed location with operator and field investigation
11	Golf courses	Fountain Spring Golf Course	none
12	Cemeteries	Cemetery near I.P.C.C. Lindside Church	none
13	Cemeteries	Cemetery with no sign	offset 100 feet south
14	Other	Fountain Spring Industrial Park	none
15	Wastewater Treatment Plant	Wastewater Treatment Plant	none

List of Regulated PSSCs

Regulated No.	Site Name	Site Description	Regulation ID	Comments
R-1	Above Ground Storage Tank *	Peterstown Middle School	032-00000020 2014-0014163	[REDACTED]
R-2	Leaking Underground Storage Tank	Bob's Grocery	92-215-L32	Cleanup initiated 9/23/1992
R-3	USEPA Regulated Site	Lindside Wastewater Collection	110055011623	US Route 219
R-4	USEPA Regulated Site	Metal Storage Building	110055012855	US Highway 21
R-5	USEPA Regulated Site	Bob's Grocery	110054959176	Route 219
<p>* Above ground storage tank (AST) information is to be kept confidential as required by WV Code. Any person who makes an unauthorized disclosure of the AST data is guilty of a misdemeanor and upon conviction thereof, may be fined not more than \$1,000 or confined in a regional jail facility for not more than twenty days, or both (§22-30-14).</p>				

APPENDIX B. EARLY WARNING MONITORING SYSTEM FORMS

Select and Attach the Appropriate Form for Your System

Form A-Complete if you currently have an early warning monitoring system installed for a surface water source

Form B-If you do not currently have an early warning monitoring system installed for a surface water intake or are planning to upgrade or replace your current system, complete this form.

Form C-Complete if you currently have an early warning monitoring system for a groundwater source.

Form D- If you do not currently have an early warning monitoring system installed for a groundwater source or are planning to upgrade or replace your current system, complete this form.

Note: You may need to fill out and attach more than one form to your Protection Plan, depending on your current situation.

Appendix B-Form B

Proposed Early Warning Monitoring System Worksheet- Surface Water Source

Describe the type of early warning detection equipment that could be installed, including the design.
The early warning detection equipment that could be installed includes a level controller, display module, back panel, level & trough along with conductivity, oil-in-water, ORP, and pH sensors
Where would the equipment be located?
Early warning monitoring systems would be located on the raw water intake line where Rich Creek and Hancock Spring surface water would enter the laboratory in the water treatment facility.
What would the maintenance plan for the monitoring equipment entail?
The proposed maintenance plan for the monitoring equipment shall consist of annual cleaning and/or exchanging of the probe(s) for the controller. Periodic calibration of the unit may also be required.
Describe the proposed sampling plan at the monitoring site.
Sampling of water quality data occurs every fifteen minutes. The PSD would need to retrieve data from the "History" of the controller data collector twice per month.
Describe the proposed procedures for data management and analysis.
Data management for the early warning monitoring system consists of data points (up to 500 points or approximately six months per probe) being recorded in the "History" of the controller data collector. To access the "History", the probe has to be plugged into the controller. Data is able to be removed via USB or through a local SCADA system.

Appendix B-Form D**Proposed Early Warning Monitoring System Worksheet- Groundwater Source**

Describe the type of ground water monitoring network that could be installed, including the design and location.
The groundwater monitoring network that could be installed would be a self-contained, configurable water resources lab with data acquisition and communication.
How many monitoring (sentinel) wells would need to be established?
In the Coburn Springs and Hancock Spring eight (8) monitoring sentinel wells.
What is the expected rate of travel of a contaminant through the groundwater system?
N/A
Provide the distance from the contaminant source to the proposed monitoring wells.
N/A
What is the distance from the proposed monitoring equipment to the wellhead?
Within a radius of 40 feet from the well head.
What would the maintenance plan for the monitoring equipment entail?
The system would be connected to the telemetry and a visual inspection would be conducted routinely.
Describe the proposed sampling plan at the monitoring site.
The system would take samples and test every five (5) minutes.
Describe the proposed procedures for data management and analysis.
Data would be collected and stored on an on-site hard drive for each reading. The data would be able to be viewed through the telemetry.

APPENDIX C. COMMUNICATION PLAN TEMPLATE

Red Sulphur PSD

PWSID: WV3303206 District: Beckley, District 1

Certified Operator: Porter Robertson

Contact Phone Number: 304-753-5981

Contact Email Address: probertson4@rocketmail.com

Plan Developed On: February 2016 Plan Update: _____

ACKNOWLEDGMENTS:

This plan was developed by Red Sulphur PSD to meet certain requirements of the Source Water and Assessment Protection Program (SWAPP) and the Wellhead Protection Program (WHPP) for the State of West Virginia, as directed by the federal Safe Drinking Water Act (SDWA) and state laws and regulations.

TABLE OF CONTENTS

INTRODUCTION.....	1
TIERS REPORTING SYSTEM	1
COMMUNICATION TEAM.....	2
COMMUNICATION TEAM DUTIES	3
INCIDENT / EVENT COMMUNICATION PROCEDURE	3
TIERS FLOW CHART	5
EMERGENCY SHORT FORMS	6
EMERGENCY CONTACT INFORMATION.....	10
PRESS RELEASE ATTACHMENTS	11

INTRODUCTION

Legislative Rule 64CSR3 requires public water systems to develop a Communication Plan that documents how public water suppliers, working in concert with state and local emergency response agencies, shall notify state and local health agencies and the public in the event of a spill or contamination event that poses a potential threat to public health and safety. The plan must indicate how the public water supplier will provide updated information, with an initial notification to the public to occur no later than thirty minutes after the supplier becomes aware that the spill, release or potential contamination of the public water system poses a potential threat to public health and safety.

The public water system has responsibility to communicate to the public, as well as to state and local health agencies. This plan is intended to comply with the requirements of Legislative Rule 64CSR3, and other state and federal regulations.

TIERS REPORTING SYSTEM

This water system has elected to use the *Tiered Incident / Event Reporting System* (TIERS) for communicating with the public, agencies, the media, and other entities in the event of a spill or other incident that may threaten water quality. TIERS provides a multi-level notification framework, which escalates the communicated threat level commensurate with the drinking water system risks associated with a particular contamination incident or event. TIERS also includes a procedural flow chart illustrating key incident response communication functions and how they interface with overall event response / incident management actions. Finally, TIERS identifies the roles and responsibilities for key people involved in risk response, public notification, news media and other communication.

TIERS provides an easy-to-remember five-tiered **A-B-C-D-E** risk-based incident response communication format, as described below. Table 1 provides also associated risk levels.

A = Announcement. The water system is issuing an announcement to the public and public agencies about an incident or event that may pose a threat to water quality. Additional information will be provided as it becomes available. As always, if water system customers notice anything unusual about their water, they should contact the water system

B = Boil Water Advisory. A boil water advisory has been issued by the water system. Customers may use the water for showering, bathing, and other non-potable uses, but should boil water used for drinking or cooking.

C = Cannot Drink. The water system asks that users not drink or cook with the water at this time. Non-potable uses, such as showering, bathing, cleaning, and outdoor uses are not affected.

D = Do Not Use. An incident or event has occurred affecting nearly all uses of the water. Do not use the water for drinking, cooking, showering, bathing, cleaning, or other tasks where water can come in contact with your skin. Water can be used for flushing commodes and fire protection.

E=Emergency. Water cannot be used for any reason.

Tier	Tier Category	Risk Level	Tier Summary
A	Announcement	Low	The water system is issuing an announcement to the public and public agencies about an incident or event that could pose a threat to public health and safety. Additional information will be provided as it becomes available.

B	Boil Water Advisory	Moderate	Water system users are advised to boil any water to be used for drinking or cooking, due to possible microbial contamination. The system operator will notify users when the boil water advisory is lifted.
C	Cannot Drink	High	System users should not drink or cook with the water until further notice. The water can still be used for showering, bathing, cleaning, and other tasks.
D	Do Not Use	Very High	The water should only be used for flushing commodes and fire protection until further notice. More information on this notice will be provided as soon as it is available.
E	Emergency	Extremely High	The water should not be used for any purpose until further notice. More information on this notice will be provided as soon as it is available.

COMMUNICATION TEAM

The Communication Team for the water system is listed in the table below, along with key roles. In the event of a spill or other incident that may affect water quality, the water system spokesperson will provide initial information, until the team assembles (if necessary) to provide follow-up communication.

Water system communication team members, organizations, and roles.

Team Member Name	Organization	Phone	Email	Role
Donald Evans	Monroe County Clerk	304-772-3096	devans@monroecountywv.net	Primary Spokesperson
Porter Robertson	Red Sulphur PSD	304-753-5981	probertson4@rocketmail.com	Secondary Spokesperson
				Member

In the event of a spill, release, or other incident that may threaten water quality, members of the team who are available will coordinate with the management staff of the local water supplier to:

- Collect information needed to investigate, analyze, and characterize the incident/event
- Provide information to the management staff, so they can decide how to respond
- Assist the management staff in handling event response and communication duties
- Coordinate fully and seamlessly with the management staff to ensure response effectiveness

COMMUNICATION TEAM DUTIES

The communication team will be responsible for working cooperatively with the management staff and state and local emergency response agencies to notify local health agencies and the public of the initial spill or contamination event. The team will also provide updated information related to any contamination or impairment of the source water supply or the system's drinking water supply.

According to Legislative Rule 64CSR3, the initial notification to the public will occur no later than thirty minutes after the public water system becomes aware that the spill, release or potential contamination of the public water system poses a potential threat to public health and safety.

As part of the group implementing the Source Water Protection Plan, team members are expected to be familiar with the plan, including incident/event response and communication tasks. Specifically, team members should:

- Be knowledgeable on elements of the Source Water Protection Plan and Communication Plan
- Attend team meetings to ensure up-to-date knowledge of the system and its functions
- Participate in periodic exercises that “game out” incident response and communication tasks
- Help to educate local officials, the media, and others on source water protection
- Cooperate with water supplier efforts to coordinate incident response communication
- Be prepared to respond to requests for field investigations of reported incidents
- Not speak on behalf of the water supplier unless designated as the system’s spokesperson

The primary spokesperson will be responsible for speaking on behalf of the water system to local agencies, the public, and the news media. The spokesperson should work with the management staff and the team to ensure that all communication is clear, accurate, timely, and consistent. The spokesperson may authorize and/or direct others to issue news releases or other information that has been approved by the system’s management staff. The spokesperson is expected to be on call immediately when an incident or event which may threaten water quality occurs. The spokesperson will perform the following tasks in the event of a spill, release, or other event that threatens water quality:

- Announce which risk level (A, B, C, D, or E) will apply to the public notifications that are issued
- Issue news releases, updates, and other information regarding the incident/event
- Use the news media, email, social media, and other appropriate information venues
- Ensure that news releases are sent to local health agencies and the public
- Respond to questions from the news media and others regarding the incident/event
- Appear at news conferences and interviews to explain incident response, etc.

INCIDENT / EVENT COMMUNICATION PROCEDURE

The flow chart in this section illustrates how the water system will respond when it receives a report that a spill, release, or other contamination event may have occurred. Key elements of the flow chart are described below.

Communication with agencies, the public, and the media during threat incidents

Upon initial notification of the incident/event, system managers and staff will collect information and verify the need for further investigation. Only properly trained personnel will perform onsite investigations if permitted by emergency responders. If further investigation is warranted, and the initial facts support it, the water system spokesperson will issue a public communication statement consistent with the threat level. In addition, water system personnel and partners will be dispatched to conduct reconnaissance, a threat assessment, and a threat characterization, if present. This work may include:

- Verification of the incident/event type (spill, release, etc.)
- Location of incident/event
- Type of material(s) involved in spill, release, etc.
- Quantity of material involved
- Potential of the material to move, migrate, or be transported


- Relevant time factor(s) in the risk assessment (e.g., downstream movement rate)
- Overall level of risk to water system, whether low, moderate, high, or very high
- Development of the initial risk characterization

As the flow chart indicates, several iterative cycles will occur after the initial threat assessment, including communication with local agencies and the public, further investigation of the incident, possible implementation of the water system's contingency plan, and eventual elimination of the threat and a return to normal operations. Communication activities during this period will include:

- The initial release (i.e., **A**nnouncement, **B**oil Water, **C**annot Drink, **D**o Not Use, or **E**mergency)
 - Sent to local health agencies, the public, and the news media within 30 minutes
- Notification of the local water system's source water protection and communication teams
 - If warranted by initial findings regarding the spill, release, or incident
- Notification of the WV Bureau of Public Health
 - As required
- Periodic information updates, as incident response information is received
- Updates to the applicable A-B-C-D-E advisory tier, as necessary

If time permits and the need arises, after the threat level is reduced, the water system staff, the communication and source water protection teams, and their partners may conduct a post-event review and assessment. The purpose of the review is to examine the response to the incident, relevant communication activities, and overall outcomes. Plans and procedures may be updated, altered, or adapted based on lessons learned through this process.

TIERS FLOW CHART



EMERGENCY SHORT FORMS

Emergency Communication Information

	Name	Phone Number	Email
Designated spokesperson:	Porter Robertson	(WTP) 304-753-5981 Or (PSD) 304-753-4003	probertson4@rocketmail.com
Alternate spokesperson:	Donald Evans	304-772-3096	devans@monroecountywv.net
Designated location to disseminate information to media:	<p>Countywide 911 "Code Red" mass notification system is used by the Monroe County Commission. Landline phone and cell phone text alerts are available. Those posting an alert can select alert radius by zip code or geographic area.</p> <p>Red Sulphur PSD also has "Phone Tree" phone notification system. Old, out of date phone numbers are a problem.</p> <p>Radio station FM 106.7 James Monroe High School radio – weather, ball games, can be used for notifications. Door hangers sometimes used for localized boil water alerts.</p>		
Methods of contacting affected residents:	Word of mouth	X	Posted notices
	Door-to-door canvassing		Radio
	Newspaper	X	Other
Media contacts:	Name	Title	Phone Number
	N/A	-	-

Emergency Services Contacts

	Name	Emergency Phone	Alternate Phone	Email
Local Police	Monroe County Sheriffs' Department, State Police	911	304-772-3437 or 304-772-5100	-
Local Fire Department	Peterstown Volunteer Fire Department	911	304-753-4343	-
Local Ambulance Service	Union Rescue-Monroe County Transport Station 2	911	304-772-3911	-
Hazardous Material Response Service	Peterstown Volunteer Fire Department	911	304-753-4343	-

Key Personnel

	Name	Title	Phone	Email
Key staff responsible for coordinating emergency response procedures?	Porter M. Robertson	Chief Operator	(WTP) 304-753-5981 Or (PSD) 304-753-4003	probertson4@rocketmail.com
	Kevin Belcher	PSA Director Giles County	540-599-0288	kbelcher@gilescounty.org
Staff responsible for keeping confidential PSSC information and releasing to emergency responders:	Porter M. Robertson	Chief Operator	(WTP) 304-753-5981 Or (PSD) 304-753-4003	probertson4@rocketmail.com
	Donald Evans	Monroe County Clerk	304-772-3096	devans@monroecountywv.net

Sensitive Populations

Other communities that are served by the utility:	Town of Greenville is served by PSD			
Major user/sensitive population notification:	Name	Emergency Phone	Alternate Phone	
	James Monroe High School	304-753-5182	-	
	Peterstown Middle School	304-753-4322	-	
	Peterstown Elementary School	304-753-4328	-	
	Pre-school Kids' Learning Center	304-753-4291	-	
EED District Office Contact:	Name	Phone	Email	
	John Stafford	304-256-6666 EED Central Office 304-558-2981	John.PB.Stafford@wv.gov	
OEHS Readiness Coordinator	Warren Von Dollen	304-356-4290 (main) 304-550-5607 (cell)	warren.r.vondollen@wv.gov	
Downstream Water Contacts:	Water System Name	Contact Name	Emergency Phone	Alternate Phone
	WVAWC-Bluestone Plant	John Pentasuglia, Jr.	304-466-5050	-
Are you planning on implementing the TIER system?	Yes			

Emergency Response Information

	Name	Phone
List laboratories available to perform sample analysis in case of emergency:	REI Consultants	(304) 255-2500
	WV Office of Lab Services	(304) 558-3530
	Analabs	(800)-880-6406
Has the utility developed a detailed Emergency Response Plan in accordance with the Public Health Security Bioterrorism Preparedness and Response Pan Act of 2002 that covers the following areas?	Yes, but out of date	
When was the Emergency Response Plan developed or last updated?	2000	

EMERGENCY CONTACT INFORMATION

State Emergency Spill Notification

1-800-642-3074

Office of Emergency Services

<http://www.wvdhsem.gov/>
Charleston, WV- (304) 558-5380

WV Bureau for Public Health Office of Environmental Health Services (OEHS)

www.wvdhhr.org/oehs

Readiness Coordinator- Warren Von Dollen

Phone; 304-356-4290

Cell; 304-550-5607

E-mail: warren.r.vondollen@wv.gov

Environmental Engineering Division Staff

Charleston, Central Office (304) 558-2981

Beckley, District 1 (304) 256-6666

St. Albans, District 2 (304) 722-0611

Kearneysville, District 4 (304) 725-9453

Wheeling, District 5 (304) 238-1145

Fairmont, District 6 (304) 368-2530

National Response Center - Chemical, Oil, & Chemical/Biological Terrorism

1-800-424-8802

WV State Fire Marshal's Office

1-800-233-3473

West Virginia State Police

1-304-746-2100

WV Watch – Report Suspicious Activity

1-866-989-2824

DEP Distance Calculator

<http://tagis.dep.wv.gov/pswcheck/>

PRESS RELEASE ATTACHMENTS

TIERS Levels A, B, C, D, and E

UTILITY ISSUED NOTICE – LEVEL A PUBLIC WATER SYSTEM ANNOUNCEMENT A WATER SYSTEM INVESTIGATION IS UNDERWAY

On _____ at ____:____ AM/PM, the _____ Water System began investigating an incident that may affect local water quality.

The incident involves the following situation at this location:

There are no restrictions on water use at this time. As always, if water system customers notice anything unusual about their water – such as abnormal odors, colors, sheen, etc. – they should contact the water system at _____.

At this time there is no need for concern if you have consumed or used the water.

Regular updates will be provided about this Announcement as water system staff continue their investigation. Again, there are no restrictions on water use at this time.

State Water System ID# _____ Date Distributed: _____

UTILITY ISSUED NOTICE – LEVEL B
BOIL WATER ADVISORY
A BOIL WATER ADVISORY IS IN EFFECT

On _____ at ____:____ am/pm, a water problem occurred causing contamination of your water. The areas that are affected are as follows:

Entire Water System or Other: _____

CONDITIONS INDICATE THERE IS A HIGH PROBABILITY THAT YOUR WATER IS CONTAMINATED. TESTING HAS NOT OCCURRED TO CONFIRM OR DENY THE PRESENCE OF CONTAMINATION IN YOUR WATER.

What should I do?

- **DO NOT DRINK THE WATER WITHOUT BOILING IT FIRST.** Bring all water to a boil, let it boil for one minute, and let it cool before using, or use bottled water. Boiled or bottled water should be used for drinking, making ice, brushing teeth, washing dishes, bathing, and food preparation **until further notice**. Boiling kills bacteria and other organisms in the water.

What happened?

- **The problem is related to** _____

What is being done?

- **The water system is taking the following action:** _____

What should a customer do if they have consumed or used the water?

- _____

We will inform you when you no longer need to boil your water. We anticipate resolving the problem within _____ hours/days. For more information, please contact _____ at _____ or _____ at _____.

General guidelines on ways to lessen the health risk are available from the EPA Safe Drinking Water Hotline at 1 (800) 426-4791.

Please share this information others who use this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice was distributed by _____

State Water System ID# _____ Date Distributed: _____

UTILITY ISSUED NOTICE – LEVEL C
“CANNOT DRINK” WATER NOTIFICATION
A LEVEL C WATER ADVISORY IS IN EFFECT

On _____ at ____:____ am/pm, a water problem occurred causing contamination of your water. The areas that are affected are as follows:

Entire Water System or Other: _____

CONDITIONS INDICATE THERE IS A HIGH PROBABILITY THAT YOUR WATER IS CONTAMINATED. TESTING HAS NOT OCCURRED TO CONFIRM OR DENY THE PRESENCE OF CONTAMINATION IN YOUR WATER.

What should I do?

- **DO NOT DRINK THE WATER.** You can't drink the water, but you can use it for showering, bathing, toilet-flushing, and other non-potable purposes.
- **BOILING WILL NOT PURIFY THE WATER.** Do not drink the water, even if it is boiled. The type of contamination suspected is not removed by boiling.

What happened?

- The problem is related to _____

What is being done?

- The water system is taking the following action: _____

What should a customer do if they have consumed or used the water?

- _____

We will inform you when the water is safe to drink. We anticipate resolving the problem within _____ hours/days. For more information – or to report unusual water conditions such as abnormal odors, colors, sheen, etc. – please contact _____ at _____ or _____ at _____.

Please share this information others who use this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice was distributed by _____

State Water System ID# _____ Date Distributed: _____

UTILITY ISSUED NOTICE – LEVEL D
“DO NOT USE” WATER NOTIFICATION
A LEVEL D WATER ADVISORY IS IN EFFECT

On _____ at ____:____ am/pm, a water problem occurred causing contamination of your water. The areas that are affected are as follows:

Entire Water System or Other: _____

CONDITIONS INDICATE THERE IS A HIGH PROBABILITY THAT YOUR WATER IS CONTAMINATED. TESTING HAS NOT OCCURRED TO CONFIRM OR DENY THE PRESENCE OF CONTAMINATION IN YOUR WATER.

What should I do?

- **DO NOT DRINK THE WATER.** The water is contaminated.
- **DO NOT SHOWER OR BATHE IN THE WATER.** You can't use the water for drinking, showering, or bathing. It can be used for toilet flushing and firefighting.
- **BOILING WILL NOT PURIFY THE WATER.** Do not use the water, even if it is boiled. The type of contamination suspected is not removed by boiling.

What happened?

- **The problem is related to** _____

What is being done?

- **The water system is taking the following action:** _____

What should a customer do if they have consumed or used the water?

- _____

We will inform you when the water is safe to drink. We anticipate resolving the problem within _____ hours/days. For more information – or to report unusual water conditions such as abnormal odors, colors, sheen, etc. – please contact _____ at _____ or _____ at _____.

Please share this information others who use this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice was distributed by _____

State Water System ID# _____ Date Distributed: _____

**UTILITY ISSUED NOTICE – LEVEL E
EMERGENCY WATER NOTIFICATION
A LEVEL E WATER ADVISORY IS IN EFFECT**

On _____ at ____:____ am/pm, a water problem occurred causing contamination of your water. The areas that are affected are as follows:

Entire Water System or Other: _____

CONDITIONS INDICATE THERE IS A HIGH PROBABILITY THAT YOUR WATER IS CONTAMINATED. TESTING HAS NOT OCCURRED TO CONFIRM OR DENY THE PRESENCE OF CONTAMINATION IN YOUR WATER.

What should I do?

- **DO NOT DRINK THE WATER.** The water is contaminated.
- **DO NOT USE THE WATER FOR ANY PURPOSE!** You can't use the water for drinking, showering, or bathing, or any other use – not even for toilet flushing.
- **BOILING WILL NOT PURIFY THE WATER.** Do not use the water, even if it is boiled. The type of contamination suspected is not removed by boiling.

What happened?

- The problem is related to _____

What is being done?

- The water system is taking the following action: _____

What should a customer do if they have consumed or used the water?

- _____

We will inform you when the water is safe to drink. We anticipate resolving the problem within _____ hours/days. For more information – or to report unusual water conditions such as abnormal odors, colors, sheen, etc. – please contact _____ at _____ or _____ at _____.

Please share this information others who use this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice was distributed by _____

State Water System ID# _____ Date Distributed: _____

APPENDIX D. SINGLE SOURCE FEASIBILITY STUDY



Source Water Protection Contingency Plan
Red Sulphur Public Service District
PWSID 3303206

Monroe County, West Virginia
August 2015

“This program is being presented with financial assistance as a grant from the West Virginia Department of Health and Human Resources.”



THRASHER

Title of Preparer:
Project Engineer

Name of Contractor(s)/Consultant(s) (if used):
The Thrasher Group, Inc.

I certify the information in the source water protection plan is complete and accurate to the best of my knowledge.

Signature of responsible party or designee authorized to sign for water utility:

Print Name of Authorizing Signatory (see instructions):

Title of Authorizing Signatory:

Date of Submission:
09/30/2015

TABLE OF CONTENTS

EXECUTIVE SUMMARY	1
PURPOSE	2
What are the benefits of preparing a Source Water Protection Plan?	2
BACKGROUND: WV SOURCE WATER ASSESSMENT AND PROTECTION PROGRAM	3
STATE REGULATORY REQUIREMENTS	3
SYSTEM INFORMATION	4
Table 1 – Population Served by the Red Sulphur PSD.....	4
WATER TREATMENT AND STORAGE	5
Table 2 – Red Sulphur PSD Water Treatment Information.....	6
Table 3 – Red Sulphur PSD Surface Water Sources.....	7
Table 4 – Red Sulphur PSD Groundwater Sources	7
Response Networks and Communication	8
Table 5 – Red Sulphur PSD Water Shortage Response Capability	8
Operation During Loss of Power	9
Table 6 – Generator Capacity	9
Future Water Supply Needs	10
Table 7 – Future Water Supply Needs for the Red Sulphur PSD	11
Water Loss Calculation.....	11
Table 8 – Water Loss Information	12
Early Warning Monitoring System	13
Table 9 – Early Warning Monitoring System Capabilities.....	14
SINGLE SOURCE FEASIBILITY STUDY	15
CONCLUSION & RECOMMENDATION	15
APPENDIX A – EARLY WARNING MONITORING SYSTEM FORMS	17
APPENDIX B – FEASIBILITY STUDY MATRIX	51
APPENDIX C – ALTERNATIVES ANALYSIS	53
APPENDIX D – SUPPORTING DOCUMENTATION	59

EXECUTIVE SUMMARY

This Source Water Protection Contingency Plan is being developed for Red Sulphur Public Service District (District), and is to be included as a portion of the complete Source Water Protection Plan (SWPP) being completed by other parties (per the West Virginia Bureau for Public Health).

The District is a state regulated public utility and operates a public water system serving the areas of Peterstown, Ballard, Bozoo, Lindside, Rock Camp, Pine Grove Road, Dry Pond, Kibble Hill, Coulters Chapel, Weikle and Greenville areas of Monroe County. The District serves 2,070 residential customers and 122 commercial customers as reported in the 2014 Public Service Commission (PSC) annual report.

The water treatment facility for the district obtains surface water from two (2) raw water intakes: Hancock Spring and Coburn Spring. Hancock Spring and Coburn Spring are the primary sources with Rich Creek being operated as a backup source. The District also obtains water from one (1) groundwater source which is only used to supplement Hancock Spring during low flow conditions. The plant has a treatment capacity of 1,000,000 gallons per day and pumps approximately 9 hours per day on average. The facility currently produces an average of 350,000 gallons per day. The District maintains eight (8) treated water storage tanks totaling 1,318,000 gallons of treated water and has one (1) raw water storage tank totaling 300,000 gallons of raw water. Currently, the water system is experiencing 26.69% unaccounted for water; however, the District is conducting leak detection and making necessary repairs to reduce the unaccounted for water.

The District currently maintains a 350 kW stationary generator which is connected to an 800 amp automatic transfer switch to provide power service to the treatment facility. A 100 kW portable generator owned by the District can connect to all booster stations in the system. It is moved to each station to provide backup power and maintain operation during power outages.

The alternative with the highest final score of feasibility is the existing backup intake on Rich Creek. The District currently has sufficient alternative water sources in place. In addition to maintaining this existing alternative water source, it is recommended that the District install an early warning monitoring system upstream of the primary intake. An early warning system can be used to notify the District of a contamination event before it reaches the intake or plant which will reduce the impact to the water system. Further explanations of the costs are provided in Appendix D, "Supporting Documentation".

Backup Intake

The District currently uses Hancock Spring and Coburn Spring intake as their primary source of surface water, and is able to use the Rich Creek surface water intake as a backup. The Rich Creek intake can fully sustain the District raw water supply demand.

Interconnection

The District is currently interconnected with the Giles County Virginia Public Service Authority (PSA) system. After analysis of treatment capacities and average water production of the Giles County PSA system, it was concluded that the Giles County PSA treatment facility would be able to provide 100 percent of water capacity demands to all areas of the Red Sulphur PSD system.

Treated Water Storage

The District currently has 1,318,000 gallons of treated water storage, which meets the minimum storage requirements that are required by Senate Bill 373. Senate Bill 373 requires two (2) days of storage based on maximum amount of water produced.

Raw Water Storage

To satisfy the minimum required raw water storage capacity, the District needs 1,034,000 gallons of storage. The District currently has 300,000 gallons of raw water storage available. The District would need to add 734,000 gallons of raw water storage.

This SWPP describes in detail the aforementioned aspects of the District, analyzes alternatives for sources of water supply, and compares alternatives in a feasibility matrix to determine the most suitable and feasible alternative for the District. Further details are provided of the selection of this alternative in the “Conclusion and Recommendation” section of this report.

PURPOSE

The goal of the West Virginia Bureau for Public Health (WV BPH) Source Water Assessment and Protection (SWAP) program is to prevent degradation of source waters which may preclude present and future uses of drinking water supplies to provide safe water in sufficient quantity to users. The most efficient way to accomplish this goal is to encourage and oversee source water protection on a local level. Every aspect of source water protection is best addressed by engaging local stakeholders.

The intent of this document is to describe what the District has done, is currently doing, and plans to do to protect its source of drinking water. Although this water system treats the water to meet federal and state drinking water standards, conventional treatment does not fully eradicate all potential contaminants, and treatment that goes beyond conventional methods is often very expensive. By completing this plan, the District acknowledges that implementing measures to prevent contamination can be a relatively economical way to help ensure the safety of the drinking water.

What are the benefits of preparing a Source Water Protection Plan?

- Fulfills the requirement for the public water utilities to complete or update their source water protection plan.
- Identifies and prioritizes potential threats to the source of drinking water; and establishes strategies to minimize the threats.
- Plans for emergency responses to incidents that compromise the water supply by contamination or depletion, including how the public, state, and local agencies will be informed.
- Plans for future expansion and development, including establishing secondary sources of water.
- Ensures conditions to provide the safest and highest quality drinking water to customers at the lowest possible cost.
- Provides more opportunities for funding to improve infrastructure, purchase land in the protection area, and other improvements to the intake or source water protection areas.

BACKGROUND: WV SOURCE WATER ASSESSMENT AND PROTECTION PROGRAM

Since 1974, the federal Safe Drinking Water Act (SDWA) has set minimum standards on the construction, operation, and quality of water provided by public water systems. In 1986, Congress amended the SDWA. A portion of those amendments was designed to protect the source water contribution areas around groundwater supply wells. This program eventually became known as the Wellhead Protection Program (WHPP). The purpose of the WHPP is to prevent pollution of the source water supplying the wells.

The Safe Drinking Water Act Amendments of 1996 expanded the concept of wellhead protection to include surface water sources under the umbrella term of “Source Water Protection”. The amendments encourage states to establish SWAP programs to protect all public drinking water supplies. As part of this initiative, states must explain how protection areas for each public water system will be delineated, how potential contaminant sources will be inventoried, and how susceptibility ratings will be established.

In 1999, the WVBPH published the West Virginia Source Water Assessment and Protection Program, which was endorsed by the United States Environmental Protection Agency. Over the next few years, WVBPH staff completed an assessment (i.e., delineation, inventory and susceptibility analysis) for all of West Virginia’s public water systems. Each public water system was sent a copy of its assessment report. Information regarding assessment reports for the Red Sulphur PSD can be found in **Table 1**.

STATE REGULATORY REQUIREMENTS

On June 6, 2014, §16.1.2 and §16.1.9a of the Code of West Virginia (1931) was reenacted and amended by adding three new sections designated §16.1.9c, §16.1.9d and §16.1.9e. The changes to the code outline specific requirements for public water utilities that draw water from a surface water source or a groundwater source influenced by surface water (GUIDI).

Under the amended and new codes, each existing public water utility using surface water or ground water influenced by surface water as a source must have completed or updated a source water protection plan by July 1, 2016, and must continue to update their plan every three years. Existing source water protection plans have been developed for many public water utilities in the past. If available, these plans were reviewed and considered in the development of this updated contingency plan. Any new water system established after July 1, 2016 must submit a source water protection plan before they begin operation. A new plan is also required when there is a significant change in the potential sources of significant contamination (PSSC) within the zone of critical concern (ZCC).

The code also requires that public water utilities include details regarding PSSCs, protection measures, system capacities, contingency plans, and communication plans. Before a plan can be approved, the local health department and public will be invited to contribute information for consideration. In some instances, public water utilities may be asked to conduct independent studies of the source water protection area and specific threats to gain additional information.

SYSTEM INFORMATION

The District is classified as a state regulated public utility and operates a public water system serving the areas of Peterstown, Ballard, Bozoo, Lindside, Rock Camp, Pine Grove Road, Dry Pond, Kibble Hill, Coulters Chapel, Weikle and Greenville. A public water system is defined as “any water supply or system which regularly supplies or offers to supply water for human consumption through pipes or other constructed conveyance, if serving at least an average of twenty-five individuals per day for at least sixty days per year, or which has at least fifteen service connections, and shall include i) any collection, treatment, storage and distribution facilities under the control of the owner or operator of the system and used primarily in connection with the system; and ii) any collection or pretreatment storage facilities not under such control which are used primarily in connection with the system.” A public water utility is defined as “a public water system which is regulated by the West Virginia Public Service Commission.” For purposes of this source water protection plan, public water systems are also referred to as public water utilities. Information on the population served by this utility is presented in **Table 1** below.

Table 1 – Population Served by The Red Sulphur Public Service District

Administrative office location:		200 Market Street Peterstown, West Virginia 24963	
Is the system a public utility, according to the Public Service Commission rule?		Public Utility PSD	
Date of Most Recent Source Water Assessment Report:		March 2005 By Bureau for Public Health	
Date of Most Recent Source Water Protection Plan:		April 2011	
Population served directly:		2,070 Residential; 122 Commercial 2,192 Total Customers	
Bulk Water Purchaser Systems:	System Name	PWSID Number	Population
	N/A	N/A	N/A
	N/A	N/A	N/A
Total Population Served by the Utility:		5,352	

<p>Does the utility have multiple source water protection areas (SWPAs)?</p>	<p>Yes</p>
<p>How many SWPAs does the utility have?</p>	<p>Four (4)-Rich Creek, Coburn Spring, Hancock Spring, Well at the plant</p>

WATER TREATMENT AND STORAGE

As required, the District has assessed their system (e.g., treatment capacity, storage capacity, unaccounted for water, contingency plans) to evaluate their ability to provide drinking water and protect public health.

Table 2 contains information on the water treatment methods and capacity of the utility. Information about the surface water sources from which the District draws water can be found in **Table 3**. If the District draws water from any groundwater sources to blend with the surface water, the information about these ground water sources can be found in **Table 4**.

Table 2 – The Red Sulphur Public Service District Water Treatment Information

Water Treatment Process (List in order)	<p style="text-align: center;">Raw Water Intake and/or Spring ↓ Raw Water Storage ↓ Aeration ↓ Coagulation ↓ Flocculation ↓ Sedimentation ↓ Filtration ↓ Post-Chlorination and Fluoride ↓ Clear Well</p>
Current Treatment Capacity (gal/day)	1,000,000 GPD
Current Average Production (gal/day)	350,000 GPD
Maximum Quantity Treated and Produced (gal)	517,000 GPD
Minimum Quantity Treated and Produced (gal)	287,000 GPD
Average Hours of Operation	9 hours per day
Maximum Hours of Operation in One Day	12 hours per day
Minimum Hours of Operation in One Day	0 hours per day
Number of Storage Tanks Maintained	8
Total Gallons of Treated Water Storage (gal)	1,318,000 GAL
Total Gallons of Raw Water Storage (gal)	300,000 GAL

Table 3 – The Red Sulphur Public Service District Surface Water Sources

Intake Name	SDWIS #	Local Name	Describe Intake	Name of Water Source	Date Constructed/ Modified	Frequency of Use (Primary/ Backup/ Emergency)	Activity Status (Active/ Inactive)
Rich Creek Intake	-	Rich Creek Intake	Gravity feed with screens to raw water pump	Rich Creek	1990's	Backup	Active
Hancock Spring	-	Hancock	Gravity feed with screens to raw water pump 1992	Hancock Spring	1934,1960 /1992	Primary	Active
Coburn Spring	-	Coburn	Gravity feed with screens to raw water pump 1992	Hancock Spring	1934,1960 /1992	Primary	Active

Table 4 – The Red Sulphur Public Service District Groundwater Sources

Does the utility blend with groundwater?					Yes				
Well/Spring Name	SDWIS #	Local Name	Date Constructed/ Modified	Completion Report Available (Yes/No)	Well Depth (ft)	Casing Depth (ft)	Grout (Yes/No)	Frequency of Use (Primary/ Backup/ Emergency)	Activity Status (Active/ Inactive)
Well at the Plant	-	Plant Well	1993	No	N/A	N/A	Yes	Backup	Active

Response Networks and Communication

Statewide initiatives for emergency response, including source water related incidents, are being developed. These include the West Virginia Water/Wastewater Agency Response Network (WV WARN, see <http://www.wvwarn.org/>) and the Rural Water Association Emergency Response Team (see <http://www.wvrwa.org/>). The District has analyzed its ability to effectively respond to emergencies and this information is provided in **Table 5**.

Table 5 – Red Sulphur Public Service District Water Shortage Response Capability

Can the utility isolate or divert contamination from the intake or groundwater supply?	No
Describe the utility’s capability to isolate or divert potential contaminants:	N/A
Can the utility switch to an alternative water source or intake that can supply full capacity at any time?	Yes
Describe in detail the utility’s capability to switch to an alternative source:	The District can switch to an alternative water source by turning gate valves and remotely turning on the booster station.
Can the utility close the water intake to prevent contamination from entering the water supply?	Yes
How long can the intake stay closed?	The intake can remain closed as long as necessary. See Note Below
Describe the process to close the intake:	The gate valves are closed.
Describe the treated water storage capacity of the water system:	The current treated water storage capacity of the system consists of eight (8) tanks totaling 1,318,000 gallons.
Is the utility a member of WVRWA Emergency Response Team?	Yes
Is the utility a member of WV-WARN?	Yes
List any other mutual aid agreements to provide or receive assistance in the event of an emergency:	Mutual Aid agreement with Giles County PSA

Note: In the event the primary source is contaminated, it is recommended that the Utility evaluate the water storage on hand at that time and determine that the alternative source is sufficient to sustain the water system for the duration of shutdown.

It is suggested that, if the District does not have the capability to divert contamination from the surface water intake, pre-cast concrete bases are constructed around the raw water intake to drop booms into the water and physically divert surface contaminants from entering the raw water intake.

Operation During Loss of Power

District analyzed and examined its ability to operate effectively during a loss of power. This involved ensuring a means to supply water through treatment, storage, and distribution without creating a public health emergency. Information regarding the District’s capacity for operation during power outages is shown in **Table 6**. The District’s standby capacity would have the capability to provide power to the system as if normal power conditions existed. The District’s emergency capacity would have the capability to provide power to only the essential equipment and treatment processes to provide water to the system. Information regarding the emergency generator capacity for each utility was calculated by the WV BPH and can be found in Appendix D, “Supporting Documentation”.

Table 6 – Generator Capacity

<p>What is the type and capacity of the generator needed to operate during a loss of power?</p>	<p>The emergency generator capacity for the system is portable 100 kW and standby 350 kW.</p>	
<p>Can the utility connect to generator at intake/wellhead? If yes, select a scenario that best describes system.</p>	<p>Yes; there is a generator a 100 kw portable generator.</p>	
<p>Can the utility connect to generator at treatment facility? If yes, select a scenario that best describes system.</p>	<p>Yes; standby power is available using a Caterpillar generator.</p>	
<p>Can the utility connect to a generator in distribution system? If yes, select a scenario that best describes system.</p>	<p>Yes, a portable generator at the plant can be connected to the booster stations</p>	
<p>Does the utility have adequate fuel on hand for the generator?</p>	<p>Yes</p>	
<p>What is your on-hand fuel storage and how long will it last operating at full capacity?</p>	<p>Gallons</p>	<p>Hours</p>
	<p>180</p>	<p>36 hours</p>

Provide a list of suppliers that could provide generators and fuel in the event of an emergency:	Supplier		Contact Name	Phone Number
	Generator	Caterpillar	Walker-CAT	(304) 949-6400
	Generator	Cummins	Crosspoint	(304) 769-1012
	Fuel	RT Rogers		(304) 466-1733
	Fuel			
Does the utility test the generator(s) periodically?		Yes		
Does the utility routinely maintain the generator?		Yes		
If no scenario describing the ability to connect to generator matches the utility's system or if utility does not have ability to connect to a generator, describe plans to respond to power outages:		N/A		

If a portable generator is available through the respective county's 911 or Emergency Center, it is assumed the generator is available **only** for the utility for which this source water protection contingency plan is prepared. If more than one utility in the county uses the portable generator during power outages, it is suggested that each utility procure a generator specifically to protect their system during a power outage.

Future Water Supply Needs

When planning for potential emergencies and developing contingency plans, a utility needs to not only consider their current demands for treated water but also account for likely future needs. This could mean expanding current intake sources or developing new ones in the near future. This can be an expensive and time consuming process, and any water utility should take this into account when determining emergency preparedness. The District's has analyzed its ability to meet future water demands at current capacity and this information is included in **Table 7**.

Table 7 – Future Water Supply Needs for the Red Sulphur Public Service District

<p>Is the utility able to meet water demands with the current production capacity over the next 5 years? If so, explain how you plan to do so.</p>	<p>Yes; The Adair Road extension will add 114 customers that will require approximately 40,000 GPD. The water treatment plant is sized at 1 MGD and the current average demand is 350,000 GPD.</p>
<p>If not, describe the circumstances and plans to increase production capacity:</p>	<p>N/A</p>

Water Loss Calculation

In any public water system, there is a certain percentage of the total treated water that does not reach the customer distribution system. Some of this water is used in treatment plant processes such as backwashing filters or flushing piping, but there is usually at least a small percentage unaccounted. To measure and report on this unaccounted for water, a public utility must use the same method used in the Public Service Commission’s rule, *Rules for the Government of Water Utilities*, 150CSR7, Section 5.6. The rule defines unaccounted for water as “the volume of water introduced into the distribution system less all metered usage and all known non-metered usage which can be estimated with reasonable accuracy.”

To further clarify, metered usages are most often those that are distributed to customers. Estimated non-metered usages include water used by fire departments for fires or training, un-metered bulk sales, flushing to maintain the distribution system, backwashing filters, and cleaning settling basins. By totaling the metered and non-metered uses, the utility calculates unaccounted for water. Note: To complete annual reports submitted to the PSC, utilities typically account for known water main breaks by estimating the amount of water lost. However, for the purposes of the source water protection plan, any water lost due to leaks – even if the system is aware of how much water is lost at a main break – is not considered a use. Water lost through leaks and main breaks cannot be controlled during water shortages or other emergencies and should be included in the calculation of percentage of water loss for purposes of the source water protection plan. The data in **Table 8** is taken from the most recently submitted Red Sulphur PSD PSC Annual Report.

Table 8 – Water Loss Information

Total Water Pumped (gal)		134,664,000
Total Water Purchased (gal)		0
Total Water Pumped and Purchased (gal)		134,664,000
Water Loss Accounted for Except Main Leaks (gal)	Mains, Plants, Filters, Flushing, etc.	6,850,000
	Fire Department	90,000
	Back Washing	3,100,000
	Blowing Settling Basins	0
Total Water Loss Accounted For Except Main Leaks		10,040,000
Water Sold- Total Gallons (gal)		88,682,000
Unaccounted For Lost Water (gal)		35,942,000
Water lost from main leaks (gal)		0
Total gallons of Unaccounted for Lost Water and Water Lost from Main Leaks (gal)		35,942,000
Total Percent Unaccounted For Water and Water Lost from Main Leaks (%)		26.69 %
If total percentage of Unaccounted for Water is greater than 15%, please describe any measures that could be taken to correct this problem:		Increase inspections and replacement of older lines is being conducted.

Early Warning Monitoring System

Public water utilities are required to provide an examination of the technical and economic feasibility of implementing an early warning monitoring system. Implementing an early warning monitoring system may be approached in different ways depending upon the water utility's resources and threats to the source water. A utility may install a continuous monitoring system that will provide real-time information regarding water quality conditions. This would require utilities to analyze the data in order to establish what condition is indicative of a contamination event. Continuous monitoring will provide results for a predetermined set of parameters. The more parameters being monitored, the more sophisticated the monitoring equipment will be. When establishing a continuous monitoring system, the utility should consider the logistics of placing and maintaining the equipment and receiving output data from the equipment.

Alternately, or in addition, a utility may also pull periodic grab samples on a regular basis or in case of a reported incident. The grab samples may be analyzed for specific contaminants. A utility should examine their PSSCs to determine what chemical contaminants could pose a threat to the water source. If possible, the utility should plan in advance how those contaminants will be detected. Consideration should be given for where samples will be collected, the preservations and hold times for samples, available laboratories to analyze samples, and costs associated with the sampling event. Regardless of the type of monitoring (continuous or grab), utilities should collect samples for their source throughout the year to better understand the baseline water quality conditions and natural seasonal fluctuations. Having a baseline will help determine if changes in the water quality are indicative of a contamination event and inform the needed response.

Every utility should establish a system or process for receiving or detecting chemical threats with sufficient time to respond to protect the treatment facility and public health. All approaches to receiving and responding to an early warning should incorporate communication with facility owners and operators that pose a threat to the water quality, state and local emergency response agencies, surrounding water utilities, and the public. Communication plays an important role in knowing how to interpret data and how to respond.

The Red Sulphur PSD has analyzed its ability to monitor for and detect potential contaminants that could impact its source water. Information regarding this utility's early warning monitoring system capabilities can be found in **Table 9** and in **Appendix A**.

Table 9 – Early Warning Monitoring System Capabilities

<p>Does your system currently receive spill notifications from a state agency, neighboring water system, local emergency responders, or other facilities? If yes, from whom do you receive notices?</p>	<p>Yes; the District receives spill notifications from the WV Health Department.</p>	
<p>Are you aware of any facilities, land uses, or critical areas within your protection areas where chemical contaminants could be released or spilled?</p>	<p>Yes, Timering closeto the springs and proposed gas tramination line</p>	
<p>Are you prepared to detect potential contaminants if notified of a spill?</p>	<p>Yes</p>	
<p>List laboratories (and contact information) on which you would rely to analyze water samples in case of a reported spill.</p>	<p>Laboratories</p>	
	<p>Name</p>	<p>Contact</p>
	<p>REI Consultants</p>	<p>(304) 255-2500</p>
	<p>WV Office of Lab Services</p>	<p>(304) 558-3530</p>
<p>Analabs</p>	<p>1-(800)-880-6406</p>	
<p>Do you have an understanding of baseline or normal conditions for your source water quality that accounts for seasonal fluctuations?</p>	<p>Yes</p>	
<p>Does your utility currently monitor raw water (through continuous monitoring or periodic grab samples) at the surface water intake or from a groundwater source on a regular basis?</p>	<p>No</p>	
<p>Provide or estimate the capital and O&M costs for your current or proposed early warning system or upgraded system.</p>	<p>Capital</p>	<p>\$50,000.00</p>
	<p>Yearly O&M</p>	<p>\$750.00</p>
<p>Do you serve more than 100,000 customers? If so, please describe the methods you use to monitor at the same technical levels utilized by ORSANCO.</p>	<p>No</p>	
<p>Note: Complete appropriate Early Warning Monitoring form for your system in Appendix A (Line 71). WVAWC Can expedite water testing.</p>		

SINGLE SOURCE FEASIBILITY STUDY

If a public water utility's water supply plant is served by a single-source intake to a surface water source of supply or a surface water influenced source of supply, the submitted source water protection plan must also include an examination and analysis of the technical and economic feasibility of alternative sources of water to provide continued safe and reliable public water service in the event its primary source of supply is detrimentally affected by contamination, release, spill event or other reason. These alternatives may include a secondary intake, two days of raw or treated water storage, interconnections with neighboring systems, or other options identified on a local level. Note: a secondary intake would draw water supply from a substantially different location or water source.

In order to accomplish this requirement, utilities should examine all existing or possible alternatives and rank them by their technical, economic, and environmental feasibility. In order to have a consistent method for ranking alternatives, WV BPH has developed a feasibility study guide. This guide provides several criteria to consider for each category, organized in a scoring matrix. By completing the Feasibility Study, utilities will demonstrate the process used to examine the feasibility of each alternative. The Feasibility Study matrix is attached as **Appendix B**. Those alternatives that are ranked highest and deemed to be most feasible will then be the subject of a second, more in-depth, study to analyze the comparative costs, risks, and benefits of implementing each of the described alternatives. An alternatives analysis report providing these details is attached as **Appendix C**.

CONCLUSION & RECOMMENDATION

This report represents a detailed explanation of the required elements of the District's Source Water Protection Plan. Any supporting documentation or other materials that the District considers relevant to their plan can be found in **Appendix D**.

This source water protection plan is intended to help prepare community public water systems all over West Virginia to properly handle any emergencies that might compromise the quality of the system's source water supply. It is imperative that this plan is updated as often as necessary to reflect the changing circumstances within the water system. The protection team should continue to meet regularly and continue to engage the public whenever possible. Communities taking local responsibility for the quality of their source water are the most effective way to prevent contamination and protect a water system against contaminated drinking water. Community cooperation, sufficient preparation, and accurate monitoring are all critical components of this source water protection plan, and a multi-faceted approach is the only way to ensure that a system is as protected as possible against source water degradation.

Based from the evaluation of the existing water system, the District has two alternative water sources in place that can fully sustain the water demands in the event that Coburn and Hancock Spring is contaminated. As shown in the Feasibility Matrix in Appendix B, the alternative with the highest final score of feasibility is the backup intake on Rich Creek. The backup intake on Rich Creek will not require the District to purchase water from Giles County PSA, thus making the backup intake the desirable of the two sources. It is recommend for the District to install an early

warning monitoring system. A cost estimate is provided on the below for the early warning system.

The Giles County PSA can supply all of the District’s water supply needs for extended duration. The alternative with the second highest feasibility rating was the interconnection with Giles County PSA. The interconnection with Giles County PSA can supply all the District water supply needs for prolonged periods. A cost estimate is provided on the below for the early warning system. Further explanations of the costs are provided in Appendix D, “Supporting Documentation”.

RECOMMENDED ALTERNATIVE COST ESTIMATE

1	LS	Early Warning System	\$ 50,000
1	LS	Operation & Maintenance for Early Warning System	\$750
		TOTAL =	\$ 50,750

APPENDIX A – EARLY WARNING MONITORING SYSTEM FORMS

Select and Attach the Appropriate Form for Your System.

Form A – Complete if you currently have an early warning monitoring system installed for a surface water source.

Form B – If you do not currently have an early warning monitoring system installed for a surface water intake or plan to upgrade or replace your current system, complete this form.

Form C – Complete if you currently have an early warning monitoring system for a groundwater source.

Form D – If you do not currently have an early warning monitoring system installed for a groundwater source or plan to upgrade or replace your current system, complete this form.

Note: You may need to fill out and attach more than one form to your Protection Plan, depending on your current situation.

Appendix A – Form B

Proposed Early Warning Monitoring System Worksheet- Surface

Describe the type of early warning detection equipment that could be installed, including the design.
The early warning detection equipment that could be installed includes a level controller, display module, back panel, level & trough (see cost estimate by Hach Company in Appendix D, “Supporting Documentation”) along with conductivity, oil-in-water, ORP, and pH sensors
Where would the equipment be located?
Early warning monitoring systems would be located on the raw water intake line where Rich Creek and Hancock Spring surface water would enter the laboratory in the water treatment facility.
What would the maintenance plan for the monitoring equipment entail?
The proposed maintenance plan for the monitoring equipment shall consist of annual cleaning and/or exchanging of the probe(s) for the controller. Periodic calibration of the unit may also be required.
Describe the proposed sampling plan at the monitoring site.
Sampling of water quality data occurs every fifteen (15) minutes. The District would need to retrieve data from the “History” of the controller data collector twice per month.
Describe the proposed procedures for data management and analysis.
Data management for the early warning monitoring system consists of data points (up to 500 points or approximately six months per probe) being recorded in the “History” of the controller data collector. To access the “History”, the probe has to be plugged into the controller. Data is able to be removed via USB or through a local SCADA system.

Literature related to the development and design of early warning systems is provided on the following pages, courtesy of the American Water Works Association.

Appendix A – Form D

Proposed Early Warning Monitoring System Worksheet- Groundwater Source

Describe the type of ground water monitoring network that could be installed, including the design and location.
The groundwater monitoring network that could be installed would be a self-contained, configurable water resources lab with data acquisition and communication.
How many monitoring (sentinel) wells would need to be established?
In the Coburn Springs and Hancock Spring eight (8) monitoring sentinel wells.
What is the expected rate of travel of a contaminant through the groundwater system?
N/A
Provide the distance from the contaminant source to the proposed monitoring wells.
N/A
What is the distance from the proposed monitoring equipment to the wellhead?
Within a radius of 40 feet from the well head.
What would the maintenance plan for the monitoring equipment entail?
The system would be connected to the telemetry and a visual inspection would be conducted routinely.
Describe the proposed sampling plan at the monitoring site.
The system would take samples and test every five (5) minutes.
Describe the proposed procedures for data management and analysis.
Data would be collected and stored on an on-site hard drive for each reading. The data would be able to be viewed through the telemetry.

Literature related to the development and design of early warning systems is provided on the following pages, courtesy of the American Water Works Association.

APPENDIX B – FEASIBILITY STUDY MATRIX

Feasibility Matrix

Red Sulphur Public Service Distirct

PWSID: 3303206

Date: 42185

Completed By: Staff Engineer, The Thrasher Group Inc.

Alternative Strategy Description	Economic Criteria					Technical Criteria							Environmental Criteria					Final Score	Total Capital Cost	Comments	
	Operation and Maintenance Costs	Capital Costs	Total	Total %	Weighted Total	Permitting	Flexibility	Resilience	Institutional Requirements	Total	Total %	Weighted Total	Environmental Impacts	Aesthetic Impacts	Stakeholder Issues	Total	Total %				Weighted Total
Backup Intake	3.0	3.0	6.0	100.0%	40.0%	3.0	3.0	3.0	3.0	12.0	100.0%	40.0%	3.0	3.0	3.0	9.0	100.0%	20.0%	100.0%	\$0.0	Has interconnection with Giles County Public Service Authority
Interconnect	3.0	3.0	6.0	100.0%	40.0%	3.0	3.0	3.0	3.0	12.0	100.0%	40.0%	3.0	3.0	3.0	9.0	100.0%	20.0%	100.0%	\$0.0	Has two additonal back up sources
Treated water storage	3.0	3.0	6.0	100.0%	40.0%	3.0	3.0	3.0	3.0	12.0	100.0%	40.0%	3.0	3.0	3.0	9.0	100.0%	20.0%	100.0%	\$0.0	The minimum required storage is meet.
Raw Water Storage	3.0	2.0	5.0	83.3%	33.3%	3.0	3.0	3.0	2.7	11.7	97.2%	38.9%	3.0	2.0	2.3	7.3	81.5%	16.3%	88.5%	\$845,088.8	No need for this alternative due to the interconnection with Giles County Public Service Authority and Backup Sources
Other-	0.0	0.0	0.0	0.0%	0.0%	0.0	0.0	0.0	0.0	0.0	0.0%	0.0%	0.0	0.0	0.0	0.0	0.0%	0.0%	0.0%	\$0.0	None

Scoring:

- 0 – Not feasible. Criterion cannot be met by this alternative and removes the alternative from further consideration.
- 1 – Feasible but difficult. Criterion represents a significant barrier to successful implementation but does not eliminate it from consideration.
- 2 – Feasible. Criterion can be met by the alternative.
- 3 – Very Feasible. Criterion can be easily met by the alternative

APPENDIX C – ALTERNATIVES ANALYSIS

ANALYSIS OF ALTERNATIVES

The District currently has two (2) existing alternative sources in place that can fully sustain the current water demands of the system. The Rich Creek Intake and Giles PSA Interconnection can provide long term backup to the primary source of supply as described below.

1. Backup Intake

The District's primary surface water intake is located on Coburn and Hancock Springs. The Well at the plant is a supplemental supply to the Hancock Spring. The District has a secondary intake on Rich Creek which can supply all the District water demands. The secondary intake on Rich Creek is located up stream of any influence of Hancock Spring. Therefore, additional costs are not anticipated for this alternative.

2. Interconnection

The District is currently interconnected with the Giles County PSA via an 8" water line.

On average, the Giles County PSA water treatment facility produces 750,000 gallons per day and has treatment capacity of 2,000,000 gallons per day. If the District's system were to fully rely on the Giles County PSA treatment facility for water supply, the Giles County PSA would have to produce 390,000 gallons of water. This additional demand is still within the total capacity of Giles County PSA.

Therefore, bringing the total amount of water treated at the Giles County PSA treatment facility to:

$$750,000 \text{ GPD} + 350,000 + 40,000 \text{ GPD} = 1,140,000 \text{ GPD}$$

Therefore, the Giles County PSA is a reliable alternative source of water for the District.

3. Treated Water Storage

Senate Bill 373 requires utilities to maintain minimum treated storage capacity is equal to two (2) days of system storage based on the plant's maximum level of production experienced within the past year.

The District's current treated water storage capacity for its system consists of eight (8) water storage tanks totaling 1,318,000 gallons of treated water. On average, the water treatment plant produces 350,000 gallons per day. The maximum amount of water produced by the water treatment facility in twenty-four (24) hour period from April 2015 to April 2014 was 517,000 gallons per day, according to monthly operating reports provided by the District.

The minimum required treated water storage capacity for the system would be:

$$517,000 \text{ gallons per day} * 2 \text{ days} = 1,034,000 \text{ gallons}$$

Therefore, the system currently meets the minimum required treated water storage capacity.

A cost analysis is provided in Appendix D, "Supporting Documentation".

4. Raw Water Storage

The District's raw water storage capacity for the system consists of two (2) storage tanks totaling 300,000 gallons. As mentioned above, the water treatment plant produces 350,000 gallons per day on average and has a maximum production of 517,000 gallons per day.

The minimum raw water storage capacity is two (2) days of the systems plant's maximum level of production experienced over a twenty-four (24) period within the past year.

The minimum required raw water storage capacity for the system would be:

$$517,000 \text{ gallons per day} * 2 \text{ days} = 1,034,000 \text{ gallons}$$

Subtract the current raw water storage of 300,000 gallon from the 1,034,000 million need and the 734,000 gallons is all that is required. Since a storage tanks have predetermined sizes an 816,000 gallon tank is in the cost analysis in Appendix D, "Supporting Documentation". The Cost of 816,000 gallon storage take is \$ 927,250 dollars.

Based on the evaluation of the alternative sources, the District currently has sufficient backup water sources in place. The backup intake and the interconnection can meet the water demand needs for the District.

Feasibility Matrix

Red Sulphur Public Service Distirct

PWSID: 3303206

30-Jun-15

Matrix Completed By:

Staff Engineer, The Thrasher Groupn Inc.

Criteria	Question	Backup Intake	Feasibility	Interconnect	Feasibility	Treated Water Storage	Feasibility	Raw Water Storage	Feasibility	Other-	Feasibility
Economic Criteria											
What is the total current budget year cost to operate and maintain the PWSU (current budget year)?		\$550,531.00		\$550,531.00		\$550,531.00		\$550,531.00		\$550,531.00	
O and M Costs	Describe the major O&M cost requirements for the alternative?	Labor, Power Materials for Maintenance	3	Labor, Power Materials for Maintenance and purchase of treated water	3	Labor, Power Materials for Maintenance	3	Labor, Power Materials for Maintenance	3		0
	What is the incremental cost (\$/gal) to operate and maintain the alternative?	\$0.00	3	\$0.00	3	\$0.00	3	\$0.00	3	\$0.00	0
	Cost comparison of the incremental O&M cost to the current budgeted costs (%)	0.00%	3	0.00%	3	0.00%	3	0.00%	3	0.00%	0
O and M-Feasibility Score			3.0		3.0		3.0		3.0		0.0
Describe the capital improvements required to implement the alternative.		None		None		Done		Construction of new 816,000 gallon tank		None	
Capital Costs	What is the total capital cost for the alternative?	\$0.00	3	\$0.00	3	\$0.00	3	\$845,088.75	2	\$0.00	0
	What is the annualized capital cost to implement the alternative, including land and easement costs, convenience tap fees, etc. (\$/gal)	\$0.00	3	\$0.00	3	\$0.00	3	\$0.00	2	\$0.00	0
	Cost comparison of the alternatives annualized capital cost to the current budgeted costs (%)	0.00%	3	0.00%	3	0.00%	3	0.00%	2	0.00%	0
Capital Cost-Feasibility Score			3.0		3.0		3.0		2.0		0.0
Technical Criteria											
Permitting	Provide a listing of the expected permits required and the permitting agencies involved in their approval.	None	3	None	3	ACOE, USFW, WVDNR, WVDEP, WVSHOP, County FloodPlain	3	ACOE, USFW, WVDNR, WVDEP, WVSHOP, County FloodPlain	3		0
	What is the timeframe for permit approval for each permit?	None	3	None	3	ACOE (90 days), USFW (60 days), WVDNR (60 days), WVDEP (90 days), WVSHOP (60 Days), County FloodPlain (90 days)	3	ACOE (90 days), USFW (60 days), WVDNR (60 days), WVDEP (90 days), WVSHOP (60 Days), County FloodPlain (90 days)	3		0
	Describe the major requirements in obtaining the permits (environmental impact studies, public hearings, etc.)	None	3	None	3	Environmental Impact Studies	3	Environmental Impact Studies	3		0
	What is the likelihood of successfully obtaining the permits?	Completed	3	Completed	3	Very Good	3	Very Good	3		0
	Does the implementation of the alternative require regulatory exceptions or variances?	No	3	No	3	No	3	No	3		0
Permitting-Feasibility Score			3.0		3.0		3.0		3.0		0.0
Flexibility	Will the alternative be needed on a regular basis or only used intermittently?	Intermittently	3	Intermittently	3	Intermittently	3	Intermittently	3		0
	How will implementing the alternative affect the PWSU's current method of treating and delivering potable water including meeting Safe Drinking Water Act regulations? (ex. In the case of storage, will the alternative increase the likelihood of disinfection byproducts?)	No Impact	3	No Impact	3	No Impact	3	No Impact	3		0
Flexibility-Feasibility Score			3.0		3.0		3.0		3.0		0.0
Resilience	Will the alternative provide any advantages or disadvantages to meeting seasonal changes in demand?	Yes	3	Yes	3	No	3	no	3		0
	How resistant will the alternative be to extreme weather conditions such as drought and flooding?	Drought may limit withdrawal capacity	3	Drought may limit withdrawal capacity	3	Yes	3	Yes	3		0
	Will the alternative be expandable to meet the growing needs of the service area?	Yes	3	Yes	3	Yes	3	Yes	3		0
Resilience-Feasibility Score			3.0		3.0		3.0		3.0		0.0

Criteria	Question	Backup Intake	Feasibility	Interconnect	Feasibility	Treated Water Storage	Feasibility	Raw Water Storage	Feasibility	Other-	Feasibility
Institutional Requirements	Identify any agreements or other legal instruments with governmental entities, private institutions or other PWSU required to implement the alternative.	None	3	The Red Sulphur Public Service District has an agreement and interconnection with Giles County Public Service Authority	3	None	3	None	3		0
	Are any development/planning restrictions in place that can act as a barrier to the implementation of the alternative.	No	3	No	3	No	3	No	3		0
	Identify potential land acquisitions and easements requirements.	Completed	3	Completed	3	Property availability on site for storage tank	3	Property availability on site for storage tank	2		0
Institutional Requirements-Feasibility Score			3.0		3.0		3.0		2.7		0.0
Environmental Criteria											
Environmental Impacts	Identify any environmentally protected areas or habitats that might be impacted by the alternative.	None	3	None	3	None	3	None	3		0
Environmental Impacts-Feasibility Score			3.0		3.0		3.0		3.0		0.0
Aesthetic Impacts	Identify any visual or noise issues caused by the alternative that may affect local land uses?	None	3	None	3	None	3	Yes, construction of a storage tank would cause temporary noise issues. The visual issues would remain once the tank is constructed	2		0
	Identify any mitigation measures that will be required to address aesthetic impacts?	None	3	None	3	None	3	Tank construction will need to be completed as quick as possible	2		0
Aesthetic Impacts-Feasibility Score			3.0		3.0		3.0		2.0		0.0
Stakeholder Issues	Identify the potential stakeholders affected by the alternative.	Completed	3	Completed	3	Completed	3	Water customers and land owners	2		0
	Identify the potential issues with stakeholders for and against the alternative.	Completed	3	Completed	3	Completed	3	A rate increase may occur	2		0
	Will stakeholder concerns represent a significant barrier to implementation (or assistance) of the alternative?	Completed	3	Completed	3	Completed	3	No	3		0
Stakeholder Issues-Feasibility Score			3.0		3.0		3.0		2.3		0.0
Comments		Has interconnection with Giles County Public Service Authority		Has two additional back up sources		The minimum required storage is meet.		No need for this alternative due to the interconnection with Giles County Public Service Authority and Backup Sources		None	

Instructions: Using the expanded instructions in the "FEASIBILITY STUDY GUIDANCE DOCUMENT", complete the white and gray input cells. Rank each criteria based on the evidence provided and best professional judgement. Rank the criteria 0-3, assuming 0=not feasible and 3=most feasible. The password to edit fillable cells is "swap".

Scoring:

- 0 – Not feasible. Criterion cannot be met by this alternative and removes the alternative from further consideration.
- 1 – Feasible but difficult. Criterion represents a significant barrier to successful implementation but does not eliminate it from consideration.
- 2 – Feasible. Criterion can be met by the alternative.
- 3 – Very Feasible. Criterion can be easily met by the alternative

Matrix Explanation

The alternative analysis matrix evaluates the utility's ability to implement each of the additional sources outlined. Alternative sources are evaluated for economic, technical and environmental feasibility. The matrix uses a 0-3 rating system, with 3 being very feasible and 0 being not feasible. Each category has sub questions to develop an average for the alternative. Once all areas are evaluated, a final feasibility score is given for each of the alternatives for use in determining which option will best suit the utility needs.

Economic factors evaluated in the matrix include all information needed to fund the alternative source. The matrix considers the current utility budget available per the latest (2014) annual report, operation and maintenance costs for each alternative, and the capital needed to construct each alternative. Supporting documentation is included in Appendix D of the report which provides a breakdown of costs for each alternative that are used as capital costs in the matrix. The economic feasibility of each alternative is compared on a cost per gallon ratio. This ratio is determined by dividing the capital cost of the improvements by the total number of gallons of water produced per year. An average of the economic feasibility factors is then calculated and entered into the overall feasibility matrix found in Appendix B.

Technical criteria evaluated include permitting, flexibility, institutional and resilience factors. Permitting costs are included in all supporting documentation for each alternative source. The permitting factors included the permits that would be needed to construct the alternative source for the utility. An additional environmental factor is the feasibility of obtaining each permit. Permits were rated from 3 to 0 based on the difficulty of obtaining the permits for the project. Depending on the project area, some permits may be very difficult and costly to obtain. Flexibility factors evaluate the ability of the alternative to be used as a permanent source of water or if it can only be used on a temporary basis. The intake and interconnections can be used as both temporary and permanent sources. The alternatives' ability to help the utility during seasonal or population increases is also evaluated in the resilience factors. The alternatives that can produce additional water were rated as 3, or very feasible. Additional criteria evaluated are easements and right of ways that will need to be acquired to construct the alternative source. For interconnections and intakes right of way would be needed to lay the new waterline. The feasibility of attaining the right of way was evaluated. All technical criteria was averaged and also entered into the feasibility summary in Appendix B.

Environmental aspects for each alternative include impacts, aesthetics and stakeholders. Environmental impacts included any areas in the proposed alternative source area that are protected. Areas that are protected would have a low feasibility because the impacts could be large if the project were constructed. Aesthetics factors were noise, visual impacts and mitigation measures that could affect the projects feasibility. The aesthetic factors relate to the stakeholders factors. The stakeholders' portion of the environmental criteria involves the community and their acceptance of the new source alternative and the structures that will be constructed.

APPENDIX D – SUPPORTING DOCUMENTATION

EARLY WARNING MONITORING COST ESTIMATE

Qty.		Description	Unit Price	Total Cost
1	EA	Back Panel / Trough / Level (required)	\$ 4,350.00	\$ 4,350
1	EA	Probe Module SC1000 (6 sensors)	\$ 1,344.00	\$ 1,344
1	EA	Internal Card SC1000 (4 mA inputs)	\$ 879.00	\$ 879
1	EA	Display Module SC1000	\$ 2,770.00	\$ 2,770
1	EA	Conductivity Sensor	\$ 860.00	\$ 860
1	EA	FP360 SC Sensor, 500ppb, SS, 1.5 m Cable	\$ 17,480.00	\$ 17,480
1	EA	ORP Sensor	\$ 880.00	\$ 880
1	EA	pH Sensor, Ryton	\$ 800.00	\$ 800
1	LS	Installation	\$ 20,365.00	\$ 20,365
TOTAL =				\$ 50,000


OPERATION & MAINTENANCE COST ESTIMATE

Qty.		Description	Unit Price	Total Cost
1	LS	Annual O&M Cost	\$ 750.00	\$ 750
TOTAL =				\$ 750

In addition to the early warning system, the UTILITY should establish a baseline water quality for their sources.

Backup Intake





APPENDIX E. SUPPORTING DOCUMENTATION

Red Sulphur PSD Source Water Protection Team Meeting

Red Sulphur PSD Office, 200 Market Street, Peterstown WV

February 3, 2016, 1 pm – 2:30 pm

Attendees:

- Porter Robertson Red Sulphur PSD
- Darrell Shrewsbury Red Sulphur PSD
- Patricia Ramsey Red Sulphur PSD
- Kevin Belcher Red Sulphur PSD
- Jackie Kirby Monroe County Health Department
- Tim Wilson Monroe County Office of Emergency Services
- J.B. Buckland Property Owner
- Anthony Brown Thrasher Engineering
- John Beckman Tetra Tech, Inc.

Opening remarks, mentioned old plan from April 2011, mentioned need for a protection team and new requirements under new state rules for source water protection.

Discussed location and use of springs. Coburn Spring and Hancock Spring are about 2,000 feet apart. Coburn is below Hancock. Coburn is primary source of water, with Hancock available as needed. Rich Creek is backup source usually only needed in the summer months when the flow volumes from Coburn and Hancock Springs are naturally lower. There is also a well at the plant, but the water quality from that well is low and well water is seldom used as backup.

Recorded names and titles of new protection team members. Checked contact info.

Reviewed and discussed Local and Regulated PSSCs. Discussed potential threats from planned Mountain Valley Pipeline construction activity versus finished pipeline. Team members noted that many county residents oppose the pipeline and would be likely to turn any public forum into an anti-pipeline meeting. The protection team discussed the appropriate means to engage the public concerning the source water protection plan without having the meeting hijacked by anti-pipeline people. The proposed pipeline route would cross the eastern portion of the Rich Creek watershed.

Reviewed and discussed strategy tables 9 and 10. Deleted roadside watershed signs as strategy. PSD does do educational programs with nearby schools.

Briefly discussed the Contingency and Feasibility Study performed by Thrasher and how that information was incorporated into the source water protection plan.

Discussed the requirement to notify the public within 30 minutes of discovering contamination of the source water. PSD staff noted that there was a "Phone Tree" system in place to notify water customers by phone in case of emergency. The phone system was limited by the accuracy of the phone numbers on customers' accounts. Tim Wilson mentioned the Code Red system for Monroe County, which sends out phone alerts, or text alerts to people with cell phones. There is also a radio station at the James Monroe High School that can be used to broadcast alerts. Door hangers can be used to notify customers in small neighborhoods that might be affected by a water main break or other localized event.

Red Sulphur PSD Source Water Protection Public Meeting

PSD Office, Market St., Peterstown, March 15, 2016

Attendees:

- Howdy Henritz, Indian Creek Watershed Association
- Donald Evans, Monroe County
- Anthony Brown, Thrasher Group
- Porter Robertson, Red Sulphur PSD
- Patricia Ramsey, Red Sulphur PSD
- Darrell Shrewsbury, Red Sulphur PSD
- Jackie Kirby, Monroe County Health Department
- Kevin Belcher, Red Sulphur PSD
- John Beckman, Tetra Tech

Reviewed source water protection timeline. Discussed Charleston Water Crisis of 2014 and reasons for new source water protection legislation. Reviewed contents of plan. Summarized potential significant sources. Summarized contingency plan alternatives. Discussed 30 minute public notification requirement.

Howdy Henritz spoke about Indian Creek Watershed Association had received funding to start the Rich Creek Watershed Association. The association would be doing some water quality monitoring and public outreach projects. Mr. Henritz asked how the wellhead protection delineation had been developed.

The protection team added Howdy Henritz and Donald Evans to the team roster. Patricia Ramsey provided contact information for 2 additional team members.

Porter Robertson proposed the protection team meet again in 6 months.

The Mountain Valley Pipeline (MVP) route was discussed. Aerial photographs of the route were reviewed. The proposed route of the 42 inch natural gas pipeline will cross Rich Creek and affect several tributaries. Potential disturbances to groundwater resources are not understood at this time. Construction activity was expected to be the biggest threat. Sedimentation could be significant. Darrell Shrewsbury mentioned that the MVP would also cross near the Big Bend PSD intake.

